

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20220956  
Address: 520 NE TOWN CENTRE DR, Unit:A, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Khanh Nguyen	Partial	Friday, May 19, 2023

Informational:  
1 Misc

6-30-22 Gordon is installing silt fence  
7-20-22 AN silt fence is still in good working order  
8-4-22 AN silt fence is good but need to clean up street  
9-22-22 AN no work for development  
9-4-22 AN. No erosion control issues  
11-30-22 AN no erosion control issues  
1-5-4-23 DP no erosion control issues  
1-18-23 DP no erosion control issues  
3-31-23 DP. Erosion control issues have been handled and is currently in good working order.  
4-3-23 NS. No Erosion control issues.  
5-19-23 NS. ESC is currently in good working order.

Corrective Action Required:  
2 Miscellaneous  
Correction

3-9-23. DP I need a contact that I can communicate with about issues with Erosion Control. There is a storm structure at the bottom of the hill by the stop sign that has a lot of sediment not allowing water to drain. I personally made it functional last rain storm. Please send me a contact at [devon.perry@cityofLS.net](mailto:devon.perry@cityofLS.net) or 816-317-5705.

3-17-23 DP. Still have not received a contact about erosion control issues.

**Comments:**