

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220900

Address: 1035 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811037 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811039 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811041 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811043 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811045 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811047 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811049 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811051 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811053 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811055 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811033 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Tuesday, May 23, 2023

Corrective Action Required:

1	Misc	1033-Secure receptacles at garage 1035-exterior gfci at back not working, secure rec. at master bath, gap at gaurdrail over 4" 1037-Hammer arrestor at dishwasher 1041-Hammer arrestor at dishwasher, exterior gfci at back, secure receptacle at master bath 1043-Hammer arrestor at dishwasher 1047-Secure receptacle at master 1049-Secure handrail at stairs
---	------	--

Comments: