

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220956
Address: 520 NE TOWN CENTRE DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, May 23, 2023

Corrective Action Required:

1	Misc	Check all buildings: -Secure MC cable within 12" of enclosures -Address endwall corner framing not per plan. Add support for girder -Support receptacle yoke at storage space 96 **Other issues that need to be resolved: -Light pole piers inspection and underground electrical inspection not performed
---	------	---

Comments: