

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20110411, Building Permit - Commercial

Address: 400 SW LONGVIEW BLVD, Unit:109, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Mark Harding Failed Wednesday, June 08, 2011

Inspection - Codes Commercial

Corrective Action Required

1 MISC PENDING FIRE DEPARTMENT APPROVAL

APPROVED TO STOCK AND SET UP FOR TENANT ONLY

NOT APPROVED FOR PUBLIC USE

Corrective Action Required

2 MISC

1. BATHROOM- APOXY PAINT REQUIRED

2. MIRROR MAX 40" AFF.

3. COMPLETE CEILING AND VENT BATH FAN.

Corrective Action Required

3 MISC

1. COMPLETE TRANSITION THRESOLD AT END RAMP TO

FLOOR.

2. PROVIDE APPROVED LOCK AT NORTHWEST EXIT DOOR.

Comments: