



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20224767	Date:	May 24, 2023
Project Title:	LEE'S SUMMIT COMMERCE CENTER (LOGISTICS) - ZOETIS	Applicant:	
Location:	1100 NW MAIN ST, Unit:D, LEES SUMMIT, MO 64086	F.E. Moran, Inc. Fire Protection	
Type of Work:		3001 Research Rd, Suite A	
Occupancy Group:	S-1	Champaign, IL 61822	
Description:	TENANT FINISH FOR OFFICE/WAREHOUSE SPACE FOR ANIMAL CARE PRODUCTS	Primary:	
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

FM Global approved plans for Zoetis space received 5/12/2023.

2. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

Call (816) 969-1300 to schedule hydrostatic and flow testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.