

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213741
Address: 2170 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, May 25, 2023

Corrective Action Required:

1	Misc	**OK to use workout room. Pool area to remain locked until Final Inspecton is complete
		-Install permanent sign at electrical room
		-Cut exterior cleanout to grade
		-Complete corrections for all other departments
		-Label pool panel
		-Secure raceways within 12" of boxes at pool equipment

Comments: