

## ANALYTICAL REPORT

May 24, 2023

Work Order: 1GE2289

Page 1 of 3

Report To
Devon Perry City of Lee's Summit - Public Works Dept. 220 SE Green Str Lees Summit, MO 64063

Work Order Information
Date Received: 05/23/2023 10:54AM Collector: Perry, Devon Phone: (816) 969-7428 PO Number: Routine Analysis

Project : Trinity Excavating & Construction Inc

Project Number: Longview Townhomes

Analyte	Result	MRL	Batch	Method	Analyst	Analyzed	Qualifier
1GE2289-01	LVTH#1 - Line 1 - Spot 1			Matrix:Drink Wtr		Collected: 05/23/23 10:05	
Total Coliforms	<1.0 MPN/100ml	1.0	1GE1356	9223B-QT	CLJ	05/23/23 16:25	
E. Coli	<1.0 MPN/100ml	1.0	1GE1356	9223B-QT	CLJ	05/23/23 16:25	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety. Samples were preserved in accordance with 40 CFR for pH adjustment unless otherwise noted. MRL= Method Reporting Limit.

City of Lee's Summit - Public Works Dept.  
220 SE Green Str  
Lees Summit, MO 64063

May 24, 2023  
Page 2 of 3

Work Order: 1GE2289

## Certified Analyses included in this Report

Method/Matrix	Analyte	Certifications
9223B-QT in Drink Wtr		
	Total Coliforms	KS-KC,MO-KC
	E. Coli	KS-KC,MO-KC

  

Code	Description	Number	Expires
KS-KC	Kansas Department of Health and Environment-KC	E-10110	04/30/2024
KS-NT	Kansas Department of Health and Environment (NELAP)	E-10287	10/31/2023
MO-KC	Missouri Department of Natural Resources (KC)	140	04/30/2024
MO-NT	Missouri Department of Natural Resources (Newton)	10170	04/30/2026
SIA1X	Iowa Dept. of Natural Resources	95	02/01/2024

End of Report



Keystone Laboratories, Inc.

Carolyn Jackson  
Project Manager

# Keystone

205 E Van Buren St  
Centerville, IA. 52544  
Phone: 641-437-7023

[illegible]

Relinquished by: (Signature)	Date:	5-23-23	Received by: (Signature)	Date:	5-23-23	Remarks:
	Time:	10:07		Time:	10:07	
Relinquished by: (Signature)	Date:	5-23-23	Received for Lab by: (Signature)	Date:	05/23/23	
	Time:	10:54		Time:	10:54	