

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221225
Address: 1900 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Thursday, May 25, 2023

Corrective Action Required:

1	Misc	-Secure AC whip within 12" of disconnect -Provide security strike plate that comes with this door. Screw the exterior door embedded jamb brace into studs -Provide AFCI protection for all outlets required per NEC 210.12. Breakers 5,9,11,13,18,24 -Label or identify all dedicated non-gfci receptacles in garage and basement
---	------	--

Comments: