

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222155  
Address: 520 NE TOWN CENTRE DR, Unit:N, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Friday, May 26, 2023

Corrective Action Required:

1	Misc	-Approval required from Planning and Field Service Engineering -Underground electrical to light pole piers and the light pole piers themselves were never inspected by the city. Submit letter of approval from the engineer of record -Secure MC raceways within 12" of boxes. Check buildings A-D -Support loose receptacle yoke in storage unit 96
---	------	--

**Comments:**