



Alliance Fire Protection, LLC
130 w 9th Ave. Suite 101
North Kansas City, MO 64116

Phone: 913-888-0647
Fax: 913-888-0618

May 26th, 2023

To: City of Lee's Summit
Attn: Plans Reviewer

TRANSMITTAL

Project: Paragon Star #2
3201 NW Paragon Pkwy. Lee's Summit MO.

The following items are being sent:

_____	Plans	_____	Samples	_____ X	Hydraulic Calculations
_____	Specifications	_____ X	Shop Drawings	_____	Other
_____	Change Order	_____	AHJ Approved Plans		

COPIES	DATE	DESCRIPTION
1	5/25/2023	Hydraulic Calcs for Dry System
1	5/25/2023	FP Shop Drawings for Dry System

THESE ARE TRANSMITTED as checked below:

_____ X	For Approval	_____ X	For Review and Comment
_____	For Your Use	_____	For Your Information
_____	As Requested	_____	Other

Please respond to 913-888-0647 or KHull@afpsprink.com with questions or comments.

REMARKS: _____

Copy To
File:

NC 1376


Signed: _____

Karl Hull, Project Manager




Hydraulic Summary

Job Number: NC-1376
Report Description: Light Hazard (3 2nd Floor SW)

Job											
Job Number NC-1376					Designer DB						
Job Name: Paragon Star #9					State Certification/License Number						
Address 1					AHJ						
Address 2					Job Site/Building						
Address 3					Drawing Name NC-1376 Paragon Star #2 draw						
System					Remote Area(s)						
Most Demanding Sprinkler Data 5.6 K-Factor 15.40 at 7.563					Occupancy Light Hazard			Job Suffix			
Hose Allowance At Source 100.00					Density 0.100 gpm/ft ²			Area of Application 1500.00 ft ² (Actual 1102.60 ft ²)			
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>					Number Of Sprinklers Calculated 8		Number Of Nozzles Calculated 0		Coverage Per Sprinkler 154.00 ft ²		
					AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area						
											
Total Hose Streams 100.00											
System Flow Demand 147.29			Total Water Required (Including Hose Allowance) 247.29								
Maximum Pressure Unbalance In Loops 0.000											
Maximum Velocity Above Ground 17.04 between nodes 780 and 807											
Maximum Velocity Under Ground 0.85 between nodes 1 and 3											
Volume capacity of Wet Pipes 1237.66 gal			Volume capacity of Dry Pipes								
Supplies											
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi)	@	Flow (gpm)	Available (psi)	@	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
1	Water Supply	100.00	166.000	68.000		2200.00	164.281		247.29	106.232	58.050
Contractor											
Contractor Number 1		Contact Name Derek Bisoglio				Contact Title Design					
Name of Contractor: Alliance Fire Protection		Phone 816-679-8021				Extension					
Address 1 130 w 9th Ave. Suite 100		FAX									
Address 2 North Kansas City, MO 64116		E-mail dbisoglio@afpsprink.com									
Address 3		Web-Site									



Water Supply at Node 1



Hydraulic Graph

Water Supply at Node 1

Static Pressure
166.000

Residual Pressure
68.000 @ 2200.00

Available Pressure at System Demand
164.281 @ 247.29

Required Pressure at System Demand
106.232 @ 147.29

Required Pressure at System Demand (Including Hose Allowance at Source)
106.232 @ 247.29



Summary Of Outflowing Devices

Job Number: NC-1376

Report Description: Light Hazard (3 2nd Floor SW)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler	1656	22.42	15.40	5.6	16.032			
Sprinkler	1657	20.08	15.40	5.6	12.860			
Sprinkler	1658	20.18	15.40	5.6	12.984			
Sprinkler	1659	21.15	15.40	5.6	14.265			
Sprinkler	1700	16.08	15.40	5.6	8.248			
Sprinkler	1701	16.34	15.40	5.6	8.509			
Sprinkler	1702	15.64	15.40	5.6	7.803			

⇒ Most Demanding Sprinkler Data



Node Analysis

Job Number: NC-1376

Report Description: Light Hazard (3 2nd Floor SW)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	-4'-0	S	106.232	147.29
1656	31'-2	Spr(-16.032)	16.032	22.42
1657	31'-2	Spr(-12.860)	12.860	20.08
1658	31'-2	Spr(-12.984)	12.984	20.18
1659	31'-2	Spr(-14.265)	14.265	21.15
1700	31'-2	Spr(-8.248)	8.248	16.08
1701	31'-2	Spr(-8.509)	8.509	16.34
1702	31'-2	Spr(-7.803)	7.803	15.64
1703	31'-2	Spr(-7.563)	7.563	15.40
3	1'-6		103.831	
74	6'-4½	T(18'-8½)	98.630	
121	8'-6	PO(9'-11), BOR	97.670	
122	14'-0½	E(9'-4½)	95.164	
164	15'-0½	PO(7'-5)	90.833	
171	29'-11	PO(5'-0)	79.976	
184	15'-0½	PO(7'-5)	91.491	
231	29'-11	PO(7'-5)	70.725	
262	29'-11	T(7'-5)	78.560	
264	29'-11	PO(7'-5)	79.980	
273	15'-0½	PO(7'-5)	90.831	
293	15'-0½	PO(7'-5)	90.967	
373	29'-11	PO(7'-5)	79.987	
374	29'-11	T(18'-8½)	80.069	
377	29'-11	T(18'-8½)	70.714	
380	15'-0½	T(18'-8½)	90.718	
381	15'-0½	PO(7'-5)	90.827	
395	29'-11	PO(7'-5)	70.755	
400	15'-0½	PO(7'-5)	90.720	
437	29'-11	PO(7'-5)	70.692	
479	29'-11	PO(5'-0)	79.316	
494	15'-0½	PO(7'-5)	90.825	
514	15'-0½	PO(7'-5)	90.723	
555	29'-11	PO(9'-11)	70.594	
591	29'-11	PO(9'-11)	79.022	
596	15'-0½	PO(7'-5)	90.824	
616	15'-0½	PO(7'-5)	90.724	
660	29'-11	PO(5'-0)	70.417	
693	29'-11	PO(7'-5)	78.817	
698	15'-0½	PO(7'-5)	90.824	
719	15'-0½	PO(7'-5)	90.724	
767	15'-0½	T(7'-5)	90.815	
770	15'-0½	T(7'-5)	90.810	
780	29'-11	PO(7'-5)	70.203	
781	15'-0½	T(7'-5)	90.766	
784	15'-0½	T(7'-5)	90.762	
807	29'-11	PO(5'-0)	17.579	
808	29'-11	PO(5'-0)	14.221	
809	29'-11	T(7'-5)	14.033	
810	29'-11	PO(5'-0)	14.352	
811	29'-11	PO(5'-0)	15.709	
817	29'-11	PO(7'-5)	78.707	
901	29'-11	PO(5'-0)	9.333	
902	29'-11	PO(5'-0)	9.610	
903	29'-11	T(7'-5)	10.189	
904	29'-11	PO(5'-0)	8.861	
905	29'-11	PO(5'-0)	8.606	



Hydraulic Analysis

Job Number: NC-1376
Report Description: Light Hazard (3 2nd Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
Route 1								
SP	1.0490	15.40	5.72	120		0.080240	1'-3	Pf 0.501
1703	31'-2	15.40	5.6	7.563		Sprinkler,	5'-0	Pe 0.542
905	29'-11			8.606		PO(5'-0)	6'-3	Pv
BL	1.4420	15.40	3.03	120		0.017037	15'-0	Pf 0.256
905	29'-11			8.606				Pe -0.000
904	29'-11			8.861			15'-0	Pv
BL	1.4420	31.04	6.10	120		0.062321	13'-10½	Pf 1.327
904	29'-11	15.64		8.861		Flow (q) from Route 2	7'-5	Pe
903	29'-11			10.189		T(7'-5)	21'-3½	Pv
BL	1.4420	63.46	12.47	120		0.233957	9'-0	Pf 3.844
903	29'-11	32.42		10.189		Flow (q) from Route 3	7'-5	Pe
809	29'-11			14.033		T(7'-5)	16'-5	Pv
BL	1.4420	19.22	3.78	120		0.025680	12'-5	Pf 0.319
809	29'-11			14.033				Pe
810	29'-11			14.352			12'-5	Pv
BL	1.4420	39.40	7.74	120		0.096873	14'-0	Pf 1.356
810	29'-11	20.18		14.352		Flow (q) from Route 6		Pe
811	29'-11			15.709			14'-0	Pv
BL	1.4420	60.55	11.90	120		0.214504	286'-3	Pf 62.998
811	29'-11	21.15		15.709		Flow (q) from Route 7	7'-5	Pe
817	29'-11			78.707		PO(7'-5)	293'-8½	Pv
CM	2.7050	60.55	3.38	120		0.010022	11'-0	Pf 0.110
817	29'-11			78.707				Pe
693	29'-11			78.817			11'-0	Pv
CM	2.7050	76.51	4.27	120		0.015447	13'-3	Pf 0.205
693	29'-11	15.95		78.817		Flow (q) from Route 5		Pe
591	29'-11			79.022			13'-3	Pv
CM	2.7050	95.08	5.31	120		0.023090	12'-9	Pf 0.294
591	29'-11	18.57		79.022		Flow (q) from Route 17		Pe
479	29'-11			79.316			12'-9	Pv
CM	2.7050	110.78	6.18	120		0.030635	5'-10½	Pf 0.753
479	29'-11	15.70		79.316		Flow (q) from Route 18	18'-8½	Pe
374	29'-11			80.069		T(18'-8½)	24'-7	Pv
CM	2.7050	147.29	8.22	120		0.051897	43'-6	Pf 4.200
374	29'-11	36.52		80.069		Flow (q) from Route 9	37'-5	Pe 6.449
380	15'-0½			90.718		2E(9'-4½), T(18'-8½)	80'-11	Pv
CM	2.7050	137.83	7.69	120		0.045896	5'-5	Pf 0.249
380	15'-0½			90.718				Pe
293	15'-0½			90.967			5'-5	Pv
CM	2.7050	140.66	7.85	120		0.047656	11'-0	Pf 0.524
293	15'-0½	2.83		90.967		Flow (q) from Route 10		Pe
184	15'-0½			91.491			11'-0	Pv
CM	2.7050	147.29	8.22	120		0.051897	34'-4	Pf 3.239
184	15'-0½	6.63		91.491		Flow (q) from Route 21	28'-1	Pe 0.434
122	14'-0½			95.164		3E(9'-4½)	62'-5	Pv
FR	3.3340	147.29	5.41	120		0.018748	5'-6½	Pf 0.104
122	14'-0½			95.164				Pe 2.402
121	8'-6			97.670		BOR	5'-6½	Pv
FR	3.3340	147.29	5.41	120		0.018748	2'-1½	Pf 0.040
121	8'-6			97.670				Pe 0.920
74	6'-4½			98.630		f(-0.000)	2'-1½	Pv
FR	3.2600	147.29	5.66	120		0.020914	4'-10½	Pf 3.087
74	6'-4½			98.630			13'-5½	Pe 2.115
3	1'-6			103.831		BFP(-2.704), BV(13'-5½)	18'-4	Pv
UG	8.3900	147.29	0.85	140		0.000157	69'-2	Pf 0.016
3	1'-6			103.831			30'-6½	Pe 2.384
1	-4'-0			106.232		E(30'-6½), S	99'-8½	Pv
		100.00				Hose Allowance At Source		
1		247.29						
Route 2								
SP	1.0490	15.64	5.81	120		0.082600	1'-3	Pf 0.516
1702	31'-2	15.64	5.6	7.803		Sprinkler,	5'-0	Pe 0.542
904	29'-11			8.861		PO(5'-0)	6'-3	Pv
Route 3								



Hydraulic Analysis

Job Number: NC-1376
Report Description: Light Hazard (3 2nd Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
SP	1.0490	16.08	5.97	120		0.086946		1'-3" Pf 0.543
1700	31'-2	16.08	5.6	8.248		Sprinkler,		5'-0" Pe 0.542
901	29'-11			9.333		PO(5'-0)		6'-3" Pv
BL	1.4420	16.08	3.16	120		0.018461		15'-0" Pf 0.277
901	29'-11			9.333				Pe
902	29'-11			9.610				15'-0" Pv
BL	1.4420	32.42	6.37	120		0.067523		1'-1½" Pf 0.578
902	29'-11	16.34		9.610		Flow (q) from Route 4		7'-5" Pe
903	29'-11			10.189		T(7'-5)		8'-7" Pv
Route 4								
SP	1.0490	16.34	6.06	120		0.089488		1'-3" Pf 0.559
1701	31'-2	16.34	5.6	8.509		Sprinkler,		5'-0" Pe 0.542
902	29'-11			9.610		PO(5'-0)		6'-3" Pv
Route 5								
SP	1.0490	20.08	7.45	120		0.131120		1'-3" Pf 0.820
1657	31'-2	20.08	5.6	12.860		Sprinkler,		5'-0" Pe 0.542
808	29'-11			14.221		PO(5'-0)		6'-3" Pv
BL	1.4420	64.32	12.64	120		0.239844		14'-0" Pf 3.358
808	29'-11	44.24		14.221		Flow (q) from Route 15		Pe
807	29'-11			17.579				14'-0" Pv
BL	1.4420	86.74	17.04	120		0.417081		118'-9" Pf 52.624
807	29'-11	22.42		17.579		Flow (q) from Route 8		7'-5" Pe
780	29'-11			70.203		PO(7'-5)		126'-2" Pv
CM	2.7050	86.74	4.84	120		0.019486		11'-0" Pf 0.214
780	29'-11			70.203				Pe
660	29'-11			70.417				11'-0" Pv
BL	1.4420	15.95	3.13	120		0.018187		447'-0" Pf 8.400
660	29'-11			70.417		PO(7'-5)		14'-10½" Pe
693	29'-11			78.817		PO(7'-5)		461'-10½" Pv
Route 6								
SP	1.0490	20.18	7.49	120		0.132286		1'-3" Pf 0.827
1658	31'-2	20.18	5.6	12.984		Sprinkler,		5'-0" Pe 0.542
810	29'-11			14.352		PO(5'-0)		6'-3" Pv
Route 7								
SP	1.0490	21.15	7.85	120		0.144316		1'-3" Pf 0.902
1659	31'-2	21.15	5.6	14.265		Sprinkler,		5'-0" Pe 0.542
811	29'-11			15.709		PO(5'-0)		6'-3" Pv
Route 8								
SP	1.0490	22.42	8.32	120		0.160785		1'-3" Pf 1.005
1656	31'-2	22.42	5.6	16.032		Sprinkler,		5'-0" Pe 0.542
807	29'-11			17.579		PO(5'-0)		6'-3" Pv
Route 9								
CM	2.7050	70.79	3.95	120		0.013379		13'-3" Pf 0.177
660	29'-11	15.95		70.417		Flow (q) from Route 5		Pe
555	29'-11			70.594				13'-3" Pv
CM	2.7050	52.22	2.92	120		0.007620		12'-9" Pf 0.097
555	29'-11			70.594				Pe
437	29'-11			70.692				12'-9" Pv
CM	2.7050	36.52	2.04	120		0.003932		5'-7½" Pf 0.022
437	29'-11			70.692				Pe
377	29'-11			70.714				5'-7½" Pv
CM	2.7050	17.15	0.96	120		0.000971		23'-9½" Pf 0.041
377	29'-11			70.714		T(18'-8½)		18'-8½" Pe
395	29'-11			70.755				42'-6" Pv
BL	1.4420	17.15	3.37	120		0.020786		425'-7" Pf 9.232
395	29'-11			70.755		PO(7'-5)		18'-7" Pe
373	29'-11			79.987		E(3'-8½), PO(7'-5)		444'-2" Pv
CM	2.7050	36.52	2.04	120		0.003932		2'-1½" Pf 0.082
373	29'-11	19.37		79.987		Flow (q) from Route 13		18'-8½" Pe
374	29'-11			80.069		T(18'-8½)		20'-10" Pv
Route 10								
BL	1.4420	1.57	0.31	120		0.000248		18'-11" Pf 0.005
784	15'-0½	2.34		90.762		Flow (q) from Route 16		Pe
781	15'-0½			90.766				18'-11" Pv
BL	1.4420	2.34	0.46	120		0.000520		83'-11½" Pf 0.044
781	15'-0½	0.77		90.766		Flow (q) from Route 11		Pe
770	15'-0½			90.810				83'-11½" Pv



Hydraulic Analysis

Job Number: NC-1376
Report Description: Light Hazard (3 2nd Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
BL	1.4420	1.56	0.31	120		0.000247	19'-4	Pf 0.005
770	15'-0½			90.810				Pe
767	15'-0½			90.815			19'-4	Pv
BL	1.4420	2.34	0.46	120		0.000520	9'-5½	Pf 0.009
767	15'-0½	0.77		90.815		Flow (q) from Route 12	7'-5	Pe
698	15'-0½			90.824		PO(7'-5)	16'-11	Pv
CM	2.7050	2.34	0.13	120		0.000024	11'-0	Pf 0.000
698	15'-0½			90.824				Pe
596	15'-0½			90.824			11'-0	Pv
CM	2.7050	4.73	0.26	120		0.000090	11'-0	Pf 0.001
596	15'-0½	2.40		90.824		Flow (q) from Route 19		Pe
494	15'-0½			90.825			11'-0	Pv
CM	2.7050	7.16	0.40	120		0.000193	12'-0	Pf 0.002
494	15'-0½	2.42		90.825		Flow (q) from Route 20		Pe
381	15'-0½			90.827			12'-0	Pv
CM	2.7050	9.47	0.53	120		0.000324	11'-0	Pf 0.004
381	15'-0½	2.31		90.827		Flow (q) from Route 22		Pe
273	15'-0½			90.831			11'-0	Pv
BL	1.4420	2.83	0.56	120		0.000743	168'-9½	Pf 0.136
273	15'-0½			90.831		PO(7'-5)	14'-10½	Pe
293	15'-0½			90.967		PO(7'-5)	183'-7½	Pv
Route 11								
BL	1.4420	0.77	0.15	120		0.000067	40'-10	Pf 0.005
784	15'-0½	2.34		90.762		T(7'-5), Flow (q) from Route 16	29'-8½	Pe
781	15'-0½			90.766		3T(7'-5)	70'-7	Pv
Route 12								
BL	1.4420	0.77	0.15	120		0.000067	41'-3	Pf 0.005
770	15'-0½			90.810		T(7'-5)	29'-8½	Pe
767	15'-0½			90.815		3T(7'-5)	71'-0	Pv
Route 13								
CM	2.7050	19.37	1.08	120		0.001217	8'-10½	Pf 0.011
377	29'-11	17.15		70.714		Flow (q) from Route 9		Pe
231	29'-11			70.725			8'-10½	Pv
BL	1.4420	19.37	3.81	120		0.026045	274'-10	Pf 7.835
231	29'-11			70.725		PO(7'-5)	26'-0	Pe
262	29'-11			78.560		3E(3'-8½), T(7'-5)	300'-10	Pv
BL	1.4420	9.97	1.96	120		0.007626	178'-9	Pf 1.420
262	29'-11			78.560			7'-5	Pe
264	29'-11			79.980		PO(7'-5)	186'-2	Pv
CM	2.7050	19.37	1.08	120		0.001217	6'-6	Pf 0.008
264	29'-11	9.40		79.980		Flow (q) from Route 14		Pe
373	29'-11			79.987			6'-6	Pv
Route 14								
BL	1.4420	9.40	1.85	120		0.006833	188'-9	Pf 1.417
262	29'-11			78.560		T(7'-5)	18'-7	Pe
171	29'-11			79.976		E(3'-8½), PO(7'-5)	207'-4	Pv
CM	2.7050	9.40	0.52	120		0.000319	10'-0	Pf 0.003
171	29'-11			79.976				Pe
264	29'-11			79.980			10'-0	Pv
Route 15								
BL	1.4420	44.24	8.69	120		0.120008	1'-7	Pf 0.188
809	29'-11	19.22		14.033		Flow (q) from Route 1		Pe
808	29'-11			14.221			1'-7	Pv
Route 16								
CM	2.7050	9.47	0.53	120		0.000324	5'-7	Pf 0.002
380	15'-0½	137.83		90.718		Flow (q) from Route 1		Pe
400	15'-0½			90.720			5'-7	Pv
CM	2.7050	7.16	0.40	120		0.000193	12'-0	Pf 0.002
400	15'-0½			90.720				Pe
514	15'-0½			90.723			12'-0	Pv
CM	2.7050	4.73	0.26	120		0.000090	11'-0	Pf 0.001
514	15'-0½			90.723				Pe
616	15'-0½			90.724			11'-0	Pv
CM	2.7050	2.34	0.13	120		0.000024	11'-0	Pf 0.000
616	15'-0½			90.724				Pe
719	15'-0½			90.724			11'-0	Pv



Hydraulic Analysis

Job Number: NC-1376
Report Description: Light Hazard (3 2nd Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	
BL	1.4420	2.34	0.46	120	0.000520	50'-6½"	Pf 0.038
719	15'-0½"			90.724	PO(7'-5)	22'-3½"	Pe
784	15'-0½"			90.762	4E(3'-8½")	72'-10"	Pv
Route 17							
BL	1.5300	18.57	3.24	120	0.018052	447'-0"	Pf 8.427
555	29'-11"			70.594	PO(9'-11)	19'-10"	Pe
591	29'-11"			79.022	PO(9'-11)	466'-10"	Pv
Route 18							
BL	1.4420	15.70	3.08	120	0.017657	458'-9"	Pf 8.625
437	29'-11"			70.692	PO(7'-5)	29'-8½"	Pe
479	29'-11"			79.316	4E(3'-8½"), PO(7'-5)	488'-5½"	Pv
Route 19							
BL	1.4420	2.40	0.47	120	0.000547	168'-9½"	Pf 0.100
616	15'-0½"			90.724	PO(7'-5)	14'-10½"	Pe
596	15'-0½"			90.824	PO(7'-5)	183'-7½"	Pv
Route 20							
BL	1.4420	2.42	0.48	120	0.000557	168'-9½"	Pf 0.102
514	15'-0½"			90.723	PO(7'-5)	14'-10½"	Pe
494	15'-0½"			90.825	PO(7'-5)	183'-7½"	Pv
Route 21							
CM	2.7050	6.63	0.37	120	0.000168	11'-0"	Pf 0.002
273	15'-0½"	2.83		90.831	Flow (q) from Route 10	11'-0"	Pe
164	15'-0½"			90.833			Pv
BL	1.4420	6.63	1.30	120	0.003588	168'-9½"	Pf 0.659
164	15'-0½"			90.833	PO(7'-5)	14'-10½"	Pe
184	15'-0½"			91.491	PO(7'-5)	183'-7½"	Pv
Route 22							
BL	1.4420	2.31	0.45	120	0.000509	180'-7½"	Pf 0.107
400	15'-0½"			90.720	PO(7'-5)	29'-8½"	Pe
381	15'-0½"			90.827	4E(3'-8½"), PO(7'-5)	210'-4"	Pv

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51



Hydraulic Analysis

Job Number: NC-1376

Report Description: Light Hazard (3 2nd Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	

Pipe Type Legend	Units Legend		Fittings Legend	
AO Arm-Over	Diameter	Inch	ALV Alarm Valve	
BL Branch Line	Elevation	Foot	AngV Angle Valve	
CM Cross Main	Flow	gpm	b Bushing	
DN Drain	Discharge	gpm	BaV Ball Valve	
DR Drop	Velocity	fps	BFP Backflow Preventer	
DY Dynamic	Pressure	psi	BV Butterfly Valve	
FM Feed Main	Length	Foot	C Cross Flow Turn 90°	
FR Feed Riser	Friction Loss	psi/Foot	cplg Coupling	
MS Miscellaneous	HWC	Hazen-Williams Constant	Cr Cross Run	
OR Outrigger	Pt	Total pressure at a point in a pipe	CV Check Valve	
RN Riser Nipple	Pn	Normal pressure at a point in a pipe	DeV Deluge Valve	
SN Swing Nipple	Pf	Pressure loss due to friction between points	DPV Dry Pipe Valve	
SP Sprig	Pe	Pressure due to elevation difference between indicated points	E 90° Elbow	
ST Stand Pipe	Pv	Velocity pressure at a point in a pipe	EE 45° Elbow	
UG Underground			Ee1 11¼° Elbow	
			Ee2 22½° Elbow	
			f Flow Device	
			fd Flex Drop	
			FDC Fire Department Connection	
			fE 90° FireLock(TM) Elbow	
			fEE 45° FireLock(TM) Elbow	
			flg Flange	
			FN Floating Node	
			fT FireLock(TM) Tee	
			g Gauge	
			GloV Globe Valve	
			GV Gate Valve	
			Ho Hose	
			Hose Hose	
			HV Hose Valve	
			Hyd Hydrant	
			LtE Long Turn Elbow	
			mecT Mechanical Tee	
			Noz Nozzle	
			P1 Pump In	
			P2 Pump Out	
			PIV Post Indicating Valve	
			PO Pipe Outlet	
			PrV Pressure Relief Valve	
			PRV Pressure Reducing Valve	
			red Reducer/Adapter	
			S Supply	
			sCV Swing Check Valve	
			SFx Seismic Flex	
			Spr Sprinkler	
			St Strainer	
			T Tee Flow Turn 90°	
			Tr Tee Run	
			U Union	
			WirF Wirsbo	
			WMV Water Meter Valve	
			Z Cap	




Hydraulic Summary

Job Number: NC-1376
Report Description: Light Hazard (2 Dry Walkway)

Job											
Job Number NC-1376					Designer DB						
Job Name: Paragon Star #9					State Certification/License Number						
Address 1					AHJ						
Address 2					Job Site/Building						
Address 3					Drawing Name NC-1376 Paragon Star #2 draw						
System					Remote Area(s)						
Most Demanding Sprinkler Data 5.6 K-Factor 18.20 at 10.563					Occupancy Light Hazard			Job Suffix			
Hose Allowance At Source 100.00					Density 0.100 gpm/ft ²			Area of Application 1950.00 ft ² (Actual 2039.92 ft ²)			
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>					Number Of Sprinklers Calculated 12		Number Of Nozzles Calculated 0		Coverage Per Sprinkler 182.00 ft ²		
					AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area						
Total Hose Streams 100.00											
System Flow Demand 241.30				Total Water Required (Including Hose Allowance) 341.30							
Maximum Pressure Unbalance In Loops 0.000											
Maximum Velocity Above Ground 21.19 between nodes 125 and 391											
Maximum Velocity Under Ground 1.40 between nodes 1 and 3											
Volume capacity of Wet Pipes 1237.66 gal				Volume capacity of Dry Pipes 66.14 gal							
Supplies											
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi)	@	Flow (gpm)	Available (psi)	@	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
1	Water Supply	100.00	166.000	68.000		2200.00	162.881		341.30	93.563	69.318
Contractor											
Contractor Number 1		Contact Name Derek Bisoglio				Contact Title Design					
Name of Contractor: Alliance Fire Protection				Phone 816-679-8021				Extension			
Address 1 130 w 9th Ave. Suite 100				FAX							
Address 2 North Kansas City, MO 64116				E-mail dbisoglio@afpsprink.com							
Address 3				Web-Site							



Water Supply at Node 1



Hydraulic Graph

Water Supply at Node 1

Static: Pressure
166.000

Residual: Pressure
68.000 @ 2200.00

Available Pressure at System Demand
162.881 @ 341.30

Required Pressure at System Demand
93.563 @ 241.30

Required Pressure at System Demand (Including Hose Allowance at Source)
93.563 @ 341.30



Summary Of Outflowing Devices

Job Number: NC-1376

Report Description: Light Hazard (2 Dry Walkway)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler	1320	19.51	18.20	5.6	12.142			
Sprinkler	1321	19.85	18.20	5.6	12.567			
Sprinkler	1322	21.05	18.20	5.6	14.125			
Sprinkler	1333	21.72	18.20	5.6	15.045			
Sprinkler	1334	22.09	18.20	5.6	15.564			
Sprinkler	1335	23.40	18.20	5.6	17.468			
Sprinkler	1411	18.51	18.20	5.6	10.921			
Sprinkler	1412	18.83	18.20	5.6	11.306			
Sprinkler	1413	19.97	18.20	5.6	12.718			
⇒ Sprinkler	1541	18.20	18.20	5.6	10.563			
Sprinkler	1542	18.52	18.20	5.6	10.936			
Sprinkler	1543	19.64	18.20	5.6	12.305			

⇒ Most Demanding Sprinkler Data



Node Analysis

Job Number: NC-1376

Report Description: Light Hazard (2 Dry Walkway)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
1	-4'-0	S	93.563	241.30
1320	12'-0	Spr(-12.142)	12.142	19.51
1321	12'-0	Spr(-12.567)	12.567	19.85
1322	12'-0	Spr(-14.125)	14.125	21.05
1333	12'-0	Spr(-15.045)	15.045	21.72
1334	12'-0	Spr(-15.564)	15.564	22.09
1335	12'-0	Spr(-17.468)	17.468	23.40
1411	12'-0	Spr(-10.921)	10.921	18.51
1412	12'-0	Spr(-11.306)	11.306	18.83
1413	12'-0	Spr(-12.718)	12.718	19.97
1541	12'-0	Spr(-10.563)	10.563	18.20
1542	12'-0	Spr(-10.936)	10.936	18.52
1543	12'-0	Spr(-12.305)	12.305	19.64
3	1'-6		91.139	
74	6'-4½	T(18'-8½)	83.018	
111	14'-3½	E(5'-10½)	74.461	
114	7'-3½	DPV	78.764	
125	14'-3½	E(4'-4½)	42.793	
383	14'-3½	PO(3'-7)	16.149	
386	14'-3½	PO(3'-7)	16.735	
388	14'-3½	PO(3'-7)	18.883	
391	14'-3½	PO(5'-3½)	21.140	
501	14'-3½	PO(3'-7)	12.868	
504	14'-3½	PO(3'-7)	13.349	
508	14'-3½	PO(3'-7)	15.111	
510	14'-3½	PO(5'-3½)	16.963	
621	14'-3½	PO(3'-7)	11.487	
624	14'-3½	PO(3'-7)	11.923	
627	14'-3½	PO(3'-7)	13.520	
629	14'-3½	PO(5'-3½)	15.201	
736	14'-3½	PO(3'-7)	11.081	
739	14'-3½	PO(3'-7)	11.504	
742	14'-3½	PO(3'-7)	13.053	
744	14'-3½	PO(5'-3½)	14.682	



Hydraulic Analysis

Job Number: NC-1376
Report Description: Light Hazard (2 Dry Walkway)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
Route 1								
DR	1.0490	18.20	6.76	100		0.153142	3'-5½"	Pf 1.512
1541	12'-0"	18.20	5.6	10.563		Sprinkler,	6'-5"	Pe -0.994
736	14'-3½"			11.081		2E(1'-5"), PO(3'-7")	9'-10½"	Pv
BL	1.4420	18.20	3.58	100		0.032517	13'-0"	Pf 0.423
736	14'-3½"			11.081				Pe
739	14'-3½"			11.504			13'-0"	Pv
BL	1.4420	36.72	7.21	100		0.119130	13'-0"	Pf 1.549
739	14'-3½"	18.52		11.504		Flow (q) from Route 3		Pe
742	14'-3½"			13.053			13'-0"	Pv
BL	1.4420	56.36	11.07	100		0.263214	0'-10½"	Pf 1.629
742	14'-3½"	19.64		13.053		Flow (q) from Route 6	5'-3½"	Pe
744	14'-3½"			14.682		PO(5'-3½")	6'-2½"	Pv
CM	2.1570	56.36	4.95	100		0.037036	14'-0"	Pf 0.518
744	14'-3½"			14.682				Pe
629	14'-3½"			15.201			14'-0"	Pv
CM	2.1570	113.67	9.98	100		0.135590	13'-0"	Pf 1.763
629	14'-3½"	57.31		15.201		Flow (q) from Route 2		Pe
510	14'-3½"			16.963			13'-0"	Pv
CM	2.1570	174.08	15.28	100		0.298318	14'-0"	Pf 4.176
510	14'-3½"	60.41		16.963		Flow (q) from Route 5		Pe
391	14'-3½"			21.140			14'-0"	Pv
CM	2.1570	241.30	21.19	100		0.545782	26'-6"	Pf 21.654
391	14'-3½"	67.22		21.140		Flow (q) from Route 10	13'-2"	Pe
125	14'-3½"			42.793		3E(4'-4½")	39'-8"	Pv
CM	2.6350	241.30	14.20	100		0.205906	147'-11"	Pf 31.667
125	14'-3½"			42.793			5'-10½"	Pe
111	14'-3½"			74.461		E(5'-10½")	153'-9½"	Pv
FR	2.7050	241.30	13.47	100		0.181224	7'-0"	Pf 1.269
111	14'-3½"			74.461				Pe 3.035
114	7'-3½"			78.764		DPV	7'-0"	Pv
FR	2.7050	241.30	13.47	120		0.129339	1'-9"	Pf 3.857
114	7'-3½"			78.764			28'-1"	Pe 0.396
74	6'-4½"			83.018		E(9'-4½"), T(18'-8½")	29'-10"	Pv
FR	3.2600	241.30	9.27	120		0.052121	4'-10½"	Pf 6.007
74	6'-4½"			83.018			13'-5½"	Pe 2.115
3	1'-6"			91.139		BFP(-5.052), BV(13'-5½")	18'-4"	Pv
UG	8.3900	241.30	1.40	140		0.000392	69'-2"	Pf 0.039
3	1'-6"			91.139			30'-6½"	Pe 2.384
1	-4'-0"			93.563		E(30'-6½"), S	99'-8½"	Pv
		100.00				Hose Allowance At Source		
1		341.30						
Route 2								
DR	1.0490	18.51	6.87	100		0.157943	3'-5½"	Pf 1.560
1411	12'-0"	18.51	5.6	10.921		Sprinkler,	6'-5"	Pe -0.994
621	14'-3½"			11.487		2E(1'-5"), PO(3'-7")	9'-10½"	Pv
BL	1.4420	18.51	3.64	100		0.033536	13'-0"	Pf 0.436
621	14'-3½"			11.487				Pe
624	14'-3½"			11.923			13'-0"	Pv
BL	1.4420	37.34	7.33	100		0.122861	13'-0"	Pf 1.597
624	14'-3½"	18.83		11.923		Flow (q) from Route 4		Pe
627	14'-3½"			13.520			13'-0"	Pv
BL	1.4420	57.31	11.26	100		0.271432	0'-10½"	Pf 1.680
627	14'-3½"	19.97		13.520		Flow (q) from Route 8	5'-3½"	Pe
629	14'-3½"			15.201		PO(5'-3½")	6'-2½"	Pv
Route 3								
DR	1.0490	18.52	6.87	100		0.158142	3'-5½"	Pf 1.562
1542	12'-0"	18.52	5.6	10.936		Sprinkler,	6'-5"	Pe -0.994
739	14'-3½"			11.504		2E(1'-5"), PO(3'-7")	9'-10½"	Pv
Route 4								
DR	1.0490	18.83	6.99	100		0.163089	3'-5½"	Pf 1.611
1412	12'-0"	18.83	5.6	11.306		Sprinkler,	6'-5"	Pe -0.994
624	14'-3½"			11.923		2E(1'-5"), PO(3'-7")	9'-10½"	Pv
Route 5								
DR	1.0490	19.51	7.24	100		0.174207	3'-5½"	Pf 1.720
1320	12'-0"	19.51	5.6	12.142		Sprinkler,	6'-5"	Pe -0.994
501	14'-3½"			12.868		2E(1'-5"), PO(3'-7")	9'-10½"	Pv



Hydraulic Analysis

Job Number: NC-1376
Report Description: Light Hazard (2 Dry Walkway)

Pipe Type	Diameter	Flow	Velocity	HWC		Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
BL	1.4420	19.51	3.83	100		0.036990	13'-0	Pf 0.481
501	14'-3½			12.868				Pe
504	14'-3½			13.349			13'-0	Pv
BL	1.4420	39.36	7.73	100		0.135497	13'-0	Pf 1.761
504	14'-3½	19.85		13.349		Flow (q) from Route 7		Pe
508	14'-3½			15.111			13'-0	Pv
BL	1.4420	60.41	11.87	100		0.299263	0'-10½	Pf 1.852
508	14'-3½	21.05		15.111		Flow (q) from Route 9	5'-3½	Pe
510	14'-3½			16.963		PO(5'-3½)	6'-2½	Pv
Route 6								
DR	1.0490	19.64	7.29	100		0.176368	3'-5½	Pf 1.742
1543	12'-0	19.64	5.6	12.305		Sprinkler,	6'-5	Pe -0.994
742	14'-3½			13.053		2E(1'-5), PO(3'-7)	9'-10½	Pv
Route 7								
DR	1.0490	19.85	7.37	100		0.179843	3'-5½	Pf 1.776
1321	12'-0	19.85	5.6	12.567		Sprinkler,	6'-5	Pe -0.994
504	14'-3½			13.349		2E(1'-5), PO(3'-7)	9'-10½	Pv
Route 8								
DR	1.0490	19.97	7.41	100		0.181844	3'-5½	Pf 1.796
1413	12'-0	19.97	5.6	12.718		Sprinkler,	6'-5	Pe -0.994
627	14'-3½			13.520		2E(1'-5), PO(3'-7)	9'-10½	Pv
Route 9								
DR	1.0490	21.05	7.81	100		0.200383	3'-5½	Pf 1.979
1322	12'-0	21.05	5.6	14.125		Sprinkler,	6'-5	Pe -0.994
508	14'-3½			15.111		2E(1'-5), PO(3'-7)	9'-10½	Pv
Route 10								
DR	1.0490	21.72	8.06	100		0.212418	3'-5½	Pf 2.098
1333	12'-0	21.72	5.6	15.045		Sprinkler,	6'-5	Pe -0.994
383	14'-3½			16.149		2E(1'-5), PO(3'-7)	9'-10½	Pv
BL	1.4420	21.72	4.27	100		0.045103	13'-0	Pf 0.586
383	14'-3½			16.149				Pe
386	14'-3½			16.735			13'-0	Pv
BL	1.4420	43.81	8.61	100		0.165181	13'-0	Pf 2.147
386	14'-3½	22.09		16.735		Flow (q) from Route 11		Pe
388	14'-3½			18.883			13'-0	Pv
BL	1.4420	67.22	13.21	100		0.364616	0'-10½	Pf 2.257
388	14'-3½	23.40		18.883		Flow (q) from Route 12	5'-3½	Pe
391	14'-3½			21.140		PO(5'-3½)	6'-2½	Pv
Route 11								
DR	1.0490	22.09	8.20	100		0.219193	3'-5½	Pf 2.165
1334	12'-0	22.09	5.6	15.564		Sprinkler,	6'-5	Pe -0.994
386	14'-3½			16.735		2E(1'-5), PO(3'-7)	9'-10½	Pv
Route 12								
DR	1.0490	23.40	8.69	100		0.243882	3'-5½	Pf 2.408
1335	12'-0	23.40	5.6	17.468		Sprinkler,	6'-5	Pe -0.994
388	14'-3½			18.883		2E(1'-5), PO(3'-7)	9'-10½	Pv

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multipling Factor	0.713	1.16	1.33	1.51



Hydraulic Analysis

Job Number: NC-1376
Report Description: Light Hazard (2 Dry Walkway)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	

Pipe Type Legend	Units Legend	Fittings Legend
AO Arm-Over BL Branch Line CM Cross Main DN Drain DR Drop DY Dynamic FM Feed Main FR Feed Riser MS Miscellaneous OR Outrigger RN Riser Nipple SN Swing Nipple SP Sprig ST Stand Pipe UG Underground	Diameter Inch Elevation Foot Flow gpm Discharge gpm Velocity fps Pressure psi Length Foot Friction Loss psi/Foot HWC Hazen-Williams Constant Pt Total pressure at a point in a pipe Pn Normal pressure at a point in a pipe Pf Pressure loss due to friction between points Pe Pressure due to elevation difference between indicated points Pv Velocity pressure at a point in a pipe	ALV Alarm Valve AngV Angle Valve b Bushing BalV Ball Valve BFP Backflow Preventer BV Butterfly Valve C Cross Flow Turn 90° cplg Coupling Cr Cross Run CV Check Valve DelV Deluge Valve DPV Dry Pipe Valve E 90° Elbow EE 45° Elbow Ee1 11¼° Elbow Ee2 22½° Elbow f Flow Device fd Flex Drop FDC Fire Department Connection fE 90° FireLock(TM) Elbow fEE 45° FireLock(TM) Elbow flg Flange FN Floating Node fT FireLock(TM) Tee g Gauge GloV Globe Valve GV Gate Valve Ho Hose Hose Hose HV Hose Valve Hyd Hydrant LtE Long Turn Elbow mecT Mechanical Tee Noz Nozzle P1 Pump In P2 Pump Out PIV Post Indicating Valve PO Pipe Outlet PrV Pressure Relief Valve PRV Pressure Reducing Valve red Reducer/Adapter S Supply sCV Swing Check Valve SFx Seismic Flex Spr Sprinkler St Strainer T Tee Flow Turn 90° Tr Tee Run U Union WirF Wirsbo WMV Water Meter Valve Z Cap



Hydraulic Summary


Job Number: NC-1376

Report Description: Ordinary Group II (1 1st Floor SW)

Job											
Job Number NC-1376					Designer DB						
Job Name: Paragon Star #9					State Certification/License Number						
Address 1					AHJ						
Address 2					Job Site/Building						
Address 3					Drawing Name NC-1376 Paragon Star #2 draw						
System					Remote Area(s)						
Most Demanding Sprinkler Data 5.6 K-Factor 22.00 at 15.434					Occupancy Ordinary Group II			Job Suffix			
Hose Allowance At Source 250.00					Density 0.200 gpm/ft ²			Area of Application 1500.00 ft ² (Actual 1097.54 ft ²)			
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>					Number Of Sprinklers Calculated 10		Number Of Nozzles Calculated 0		Coverage Per Sprinkler 110.00 ft ²		
					AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area						
											
Total Hose Streams 250.00											
System Flow Demand 235.05			Total Water Required (Including Hose Allowance) 485.05								
Maximum Pressure Unbalance In Loops 0.000											
Maximum Velocity Above Ground 13.12 between nodes 122 and 184											
Maximum Velocity Under Ground 1.36 between nodes 1 and 3											
Volume capacity of Wet Pipes 1237.66 gal			Volume capacity of Dry Pipes								
Supplies											
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi)	@	Flow (gpm)	Available (psi)	@	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
1	Water Supply	250.00	166.000	68.000		2200.00	160.024		485.05	125.350	34.674
Contractor											
Contractor Number 1		Contact Name Derek Bisoglio				Contact Title Design					
Name of Contractor: Alliance Fire Protection		Phone 816-679-8021				Extension					
Address 1 130 w 9th Ave. Suite 100		FAX									
Address 2 North Kansas City, MO 64116		E-mail dbisoglio@afpsprink.com									
Address 3		Web-Site									



Water Supply at Node 1



Hydraulic Graph

Water Supply at Node 1

Static: Pressure

166.000

Residual: Pressure

68.000 @ 2200.00

Available Pressure at System Demand

160.024 @ 485.05

Required Pressure at System Demand

125.350 @ 235.05

Required Pressure at System Demand (Including Hose Allowance at Source)

125.350 @ 485.05



Summary Of Outflowing Devices

Job Number: NC-1376

Report Description: Ordinary Group II (1 1st Floor SW)

Device		Actual Flow (gpm)	Minimum Flow (gpm)	K-Factor (K)	Pressure (psi)			
Sprinkler	1508	24.90	22.00	5.6	19.773			
Sprinkler	1509	24.72	22.00	5.6	19.493			
Sprinkler	1510	24.72	22.00	5.6	19.492			
Sprinkler	1511	24.75	22.00	5.6	19.527			
Sprinkler	1512	24.85	22.00	5.6	19.685			
Sprinkler	1581	22.40	22.00	5.6	15.995			
Sprinkler	1582	22.06	22.00	5.6	15.524			
➡ Sprinkler	1583	22.00	22.00	5.6	15.434			
Sprinkler	1584	22.08	22.00	5.6	15.543			

➡ Most Demanding Sprinkler Data



Node Analysis

Job Number: NC-1376

Report Description: Ordinary Group II (1 1st Floor SW)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
616	15'-0½	PO(7'-5)	101.429	
631	15'-0½	PO(7'-5)	26.411	
660	29'-11	PO(5'-0)	44.328	
693	29'-11	PO(7'-5)	83.047	
698	15'-0½	PO(7'-5)	101.667	
710	15'-0½	PO(5'-0)	34.068	
712	15'-0½	PO(7'-5)	32.201	
716	15'-0½	PO(7'-5)	30.594	
719	15'-0½	PO(7'-5)	101.430	
727	15'-0½	PO(5'-0)	21.456	
728	15'-0½	PO(7'-5)	21.189	
729	15'-0½	PO(5'-0)	21.161	
730	15'-0½	PO(5'-0)	21.160	
731	15'-0½	PO(5'-0)	21.197	
732	15'-0½	PO(5'-0)	21.364	
733	15'-0½	PO(7'-5)	21.539	
738	15'-0½	PO(13'-7½)	25.973	
767	15'-0½	T(7'-5)	101.646	
770	15'-0½	T(7'-5)	101.635	
780	29'-11	PO(7'-5)	44.371	
781	15'-0½	T(7'-5)	101.531	
784	15'-0½	T(7'-5)	101.520	
817	29'-11	PO(7'-5)	83.004	
846	15'-0½	PO(5'-0)	17.466	
847	15'-0½	T(7'-5)	17.897	
848	15'-0½	PO(5'-0)	16.968	
849	15'-0½	PO(5'-0)	16.872	
850	15'-0½	PO(5'-0)	16.987	
851	15'-0½	T(7'-5)	18.102	
852	15'-0½	PO(5'-0)	17.724	
1	-4'-0	S	125.350	235.05
1508	16'-2	Spr(-19.773)	19.773	24.90
1509	16'-2	Spr(-19.493)	19.493	24.72
1510	16'-2	Spr(-19.492)	19.492	24.72
1511	16'-2	Spr(-19.527)	19.527	24.75
1512	16'-2	Spr(-19.685)	19.685	24.85
1581	16'-2	Spr(-15.995)	15.995	22.40
1582	16'-2	Spr(-15.524)	15.524	22.06
1583	16'-2	Spr(-15.434)	15.434	22.00
1584	16'-2	Spr(-15.543)	15.543	22.08
1585	16'-2	Spr(-16.239)	16.239	22.57
3	1'-6		122.928	
74	6'-4½	T(18'-8½)	115.038	
121	8'-6	PO(9'-11), BOR	114.024	
122	14'-0½	E(9'-4½)	111.375	
164	15'-0½	PO(7'-5)	101.688	
170	15'-0½	PO(7'-5)	37.103	
171	29'-11	PO(5'-0)	84.567	
184	15'-0½	PO(7'-5)	103.252	
194	15'-0½	PO(7'-5)	27.020	
231	29'-11	PO(7'-5)	43.461	
262	29'-11	T(7'-5)	78.273	
264	29'-11	PO(7'-5)	84.581	
273	15'-0½	PO(7'-5)	101.684	
276	15'-0½	PO(7'-5)	26.995	
293	15'-0½	PO(7'-5)	102.008	
298	15'-0½	PO(7'-5)	37.129	
373	29'-11	PO(7'-5)	84.617	
374	29'-11	T(18'-8½)	84.997	
377	29'-11	T(18'-8½)	43.413	
380	15'-0½	T(18'-8½)	101.417	
381	15'-0½	PO(7'-5)	101.675	



Node Analysis

Job Number: NC-1376

Report Description: Ordinary Group II (1 1st Floor SW)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
382	15'-0½	T(18'-8½)	37.337	
390	15'-0½	PO(7'-5)	35.546	
395	29'-11	PO(7'-5)	39.714	
400	15'-0½	PO(7'-5)	101.422	
411	15'-0½	PO(5'-0)	26.902	
437	29'-11	PO(7'-5)	43.720	
479	29'-11	PO(5'-0)	83.655	
494	15'-0½	PO(7'-5)	101.670	
497	15'-0½	PO(7'-5)	34.851	
514	15'-0½	PO(7'-5)	101.427	
523	15'-0½	PO(7'-5)	26.706	
555	29'-11	PO(9'-11)	44.141	
591	29'-11	PO(9'-11)	83.234	
596	15'-0½	PO(7'-5)	101.668	
605	15'-0½	PO(7'-5)	34.386	



Hydraulic Analysis

Job Number: NC-1376

Report Description: Ordinary Group II (1 1st Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
Route 1								
SP	1.0490	22.00	8.17	120		0.155224	1'-1½"	Pf 0.951
1583	16'-2	22.00	5.6	15.434		Sprinkler,	5'-0"	Pe 0.488
849	15'-0½"			16.872		PO(5'-0)	6'-1½"	Pv
BL	1.4420	10.44	2.05	120		0.008305	11'-6"	Pf 0.096
849	15'-0½"			16.872				Pe
848	15'-0½"			16.968			11'-6"	Pv
BL	1.4420	32.51	6.39	120		0.067868	6'-3"	Pf 0.930
848	15'-0½"	22.06		16.968		Flow (q) from Route 2	7'-5"	Pe
847	15'-0½"			17.897		T(7'-5)	13'-8½"	Pv
BL	1.4420	54.90	10.79	120		0.178963	10'-11½"	Pf 3.292
847	15'-0½"	22.40		17.897		Flow (q) from Route 4	7'-5"	Pe
728	15'-0½"			21.189		PO(7'-5)	18'-4½"	Pv
BL	2.2030	82.60	6.95	120		0.048369	5'-6"	Pf 0.267
728	15'-0½"	27.69		21.189		Flow (q) from Route 6		Pe
727	15'-0½"			21.456			5'-6"	Pv
BL	2.2030	107.50	9.05	120		0.078754	88'-9"	Pf 9.138
727	15'-0½"	24.90		21.456		Flow (q) from Route 10	27'-3½"	Pe
716	15'-0½"			30.594		4E(6'-10)	116'-0½"	Pv
BL	2.2030	90.62	7.63	120		0.057419	28'-0"	Pf 1.608
716	15'-0½"			30.594				Pe
712	15'-0½"			32.201			28'-0"	Pv
BL	2.2030	107.50	9.05	120		0.078754	10'-0½"	Pf 1.866
712	15'-0½"	16.88		32.201		Flow (q) from Route 22	13'-7½"	Pe
710	15'-0½"			34.068		PO(13'-7½)	23'-8½"	Pv
CM	2.7050	107.50	6.00	120		0.028980	11'-0"	Pf 0.319
710	15'-0½"			34.068				Pe
605	15'-0½"			34.386			11'-0"	Pv
CM	2.7050	131.78	7.36	120		0.042240	11'-0"	Pf 0.465
605	15'-0½"	24.28		34.386		Flow (q) from Route 26		Pe
497	15'-0½"			34.851			11'-0"	Pv
CM	2.7050	156.34	8.73	120		0.057945	12'-0"	Pf 0.695
497	15'-0½"	24.56		34.851		Flow (q) from Route 3		Pe
390	15'-0½"			35.546			12'-0"	Pv
CM	2.7050	179.85	10.04	120		0.075089	5'-1½"	Pf 1.790
390	15'-0½"	23.51		35.546		Flow (q) from Route 28	18'-8½"	Pe
382	15'-0½"			37.337		T(18'-8½)	23'-10"	Pv
CM	2.7050	235.05	13.12	120		0.123207	52'-11"	Pf 8.827
382	15'-0½"	55.20		37.337		Flow (q) from Route 15	18'-8½"	Pe
395	29'-11"			39.714		2E(9'-4½)	71'-7½"	Pv
BL	1.4420	40.32	7.92	120		0.101095	425'-7"	Pf 44.902
395	29'-11"			39.714		PO(7'-5)	18'-7"	Pe
373	29'-11"			84.617		E(3'-8½), PO(7'-5)	444'-2"	Pv
CM	2.7050	83.70	4.67	120		0.018239	2'-1½"	Pf 0.380
373	29'-11"	43.38		84.617		Flow (q) from Route 19	18'-8½"	Pe
374	29'-11"			84.997		T(18'-8½)	20'-10"	Pv
CM	2.7050	235.05	13.12	120		0.123207	43'-6"	Pf 9.972
374	29'-11"	151.35		84.997		Flow (q) from Route 11	37'-5"	Pe
380	15'-0½"			101.417		2E(9'-4½), T(18'-8½)	80'-11"	Pv
CM	2.7050	219.94	12.28	120		0.108958	5'-5"	Pf 0.591
380	15'-0½"			101.417				Pe
293	15'-0½"			102.008			5'-5"	Pv
CM	2.7050	224.46	12.53	120		0.113137	11'-0"	Pf 1.245
293	15'-0½"	4.52		102.008		Flow (q) from Route 16		Pe
184	15'-0½"			103.252			11'-0"	Pv
CM	2.7050	235.05	13.12	120		0.123207	34'-4"	Pf 7.689
184	15'-0½"	10.59		103.252		Flow (q) from Route 32	28'-1"	Pe
122	14'-0½"			111.375		3E(9'-4½)	62'-5"	Pv
FR	3.3340	235.05	8.64	120		0.044509	5'-6½"	Pf 0.247
122	14'-0½"			111.375				Pe
121	8'-6"			114.024		BOR	5'-6½"	Pv
FR	3.3340	235.05	8.64	120		0.044509	2'-1½"	Pf 0.094
121	8'-6"			114.024				Pe
74	6'-4½"			115.038		f(-0.000)	2'-1½"	Pv
FR	3.2600	235.05	9.03	120		0.049650	4'-10½"	Pf 5.775
74	6'-4½"			115.038			13'-5½"	Pe
3	1'-6"			122.928		BFP(-4.866), BV(13'-5½)	18'-4"	Pv



Hydraulic Analysis

Job Number: NC-1376

Report Description: Ordinary Group II (1 1st Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC	Pn	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt		Fittings	Eq. Length	Summary
Upstream							Total Length	
UG	8.3900	235.05	1.36	140		0.000374	69'-2"	Pf 0.037
3	1'-6"			122.928			30'-6½"	Pe 2.384
1	-4'-0"			125.350		E(30'-6½), S	99'-8½"	Pv
		250.00				Hose Allowance At Source		
1		485.05						
Route 2								
SP	1.0490	22.06	8.19	120		0.156064	1'-1½"	Pf 0.956
1582	16'-2"	22.06	5.6	15.524		Sprinkler,	5'-0"	Pe 0.488
848	15'-0½"			16.968		PO(5'-0)	6'-1½"	Pv
Route 3								
SP	1.0490	22.08	8.20	120		0.156238	1'-1½"	Pf 0.957
1584	16'-2"	22.08	5.6	15.543		Sprinkler,	5'-0"	Pe 0.488
850	15'-0½"			16.987		PO(5'-0)	6'-1½"	Pv
BL	1.4420	33.63	6.61	120		0.072284	8'-0"	Pf 1.114
850	15'-0½"	11.56		16.987		Flow (q) from Route 23	7'-5"	Pe
851	15'-0½"			18.102		T(7'-5)	15'-5"	Pv
BL	1.4420	56.20	11.04	120		0.186863	10'-11½"	Pf 3.437
851	15'-0½"	22.57		18.102		Flow (q) from Route 5	7'-5"	Pe
733	15'-0½"			21.539		PO(7'-5)	18'-4½"	Pv
BL	2.2030	127.55	10.74	120		0.108060	27'-4½"	Pf 4.434
733	15'-0½"	71.35		21.539		Flow (q) from Route 8	13'-7½"	Pe
738	15'-0½"			25.973		PO(13'-7½)	41'-0½"	Pv
CM	2.7050	127.55	7.12	120		0.039764	11'-0"	Pf 0.437
738	15'-0½"			25.973				Pe
631	15'-0½"			26.411			11'-0"	Pv
CM	2.7050	103.27	5.77	120		0.026904	11'-0"	Pf 0.296
631	15'-0½"			26.411				Pe
523	15'-0½"			26.706			11'-0"	Pv
BL	1.4420	24.56	4.82	120		0.040395	186'-9"	Pf 8.145
523	15'-0½"			26.706		PO(7'-5)	14'-10½"	Pe
497	15'-0½"			34.851		PO(7'-5)	201'-7½"	Pv
Route 4								
SP	1.0490	22.40	8.31	120		0.160441	1'-1½"	Pf 0.983
1581	16'-2"	22.40	5.6	15.995		Sprinkler,	5'-0"	Pe 0.488
846	15'-0½"			17.466		PO(5'-0)	6'-1½"	Pv
BL	1.4420	22.40	4.40	120		0.034067	5'-3"	Pf 0.432
846	15'-0½"			17.466			7'-5"	Pe
847	15'-0½"			17.897		T(7'-5)	12'-8"	Pv
Route 5								
SP	1.0490	22.57	8.38	120		0.162704	1'-1½"	Pf 0.997
1585	16'-2"	22.57	5.6	16.239		Sprinkler,	5'-0"	Pe 0.488
852	15'-0½"			17.724		PO(5'-0)	6'-1½"	Pv
BL	1.4420	22.57	4.43	120		0.034547	3'-6"	Pf 0.378
852	15'-0½"			17.724			7'-5"	Pe
851	15'-0½"			18.102		T(7'-5)	10'-11½"	Pv
Route 6								
SP	1.0490	24.72	9.18	120		0.192638	1'-1½"	Pf 1.180
1510	16'-2"	24.72	5.6	19.492		Sprinkler,	5'-0"	Pe 0.488
730	15'-0½"			21.160		PO(5'-0)	6'-1½"	Pv
BL	2.2030	2.97	0.25	120		0.000103	9'-0"	Pf 0.001
730	15'-0½"			21.160				Pe
729	15'-0½"			21.161			9'-0"	Pv
BL	2.2030	27.69	2.33	120		0.006406	4'-6"	Pf 0.029
729	15'-0½"	24.72		21.161		Flow (q) from Route 7		Pe
728	15'-0½"			21.189			4'-6"	Pv
Route 7								
SP	1.0490	24.72	9.18	120		0.192646	1'-1½"	Pf 1.180
1509	16'-2"	24.72	5.6	19.493		Sprinkler,	5'-0"	Pe 0.488
729	15'-0½"			21.161		PO(5'-0)	6'-1½"	Pv
Route 8								
SP	1.0490	24.75	9.19	120		0.192957	1'-1½"	Pf 1.182
1511	16'-2"	24.75	5.6	19.527		Sprinkler,	5'-0"	Pe 0.488
731	15'-0½"			21.197		PO(5'-0)	6'-1½"	Pv
BL	2.2030	46.50	3.91	120		0.016709	10'-0"	Pf 0.167
731	15'-0½"	21.75		21.197		Flow (q) from Route 21		Pe
732	15'-0½"			21.364			10'-0"	Pv



Hydraulic Analysis

Job Number: NC-1376

Report Description: Ordinary Group II (1 1st Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC		Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
BL	2.2030	71.35	6.01	120		0.036890	4'-9"	Pf 0.176
732	15'-0½"	24.85		21.364		Flow (q) from Route 9		Pe
733	15'-0½"			21.539			4'-9"	Pv
Route 9								
SP	1.0490	24.85	9.22	120		0.194403	1'-1½"	Pf 1.191
1512	16'-2"	24.85	5.6	19.685		Sprinkler,	5'-0"	Pe 0.488
732	15'-0½"			21.364		PO(5'-0)	6'-1½"	Pv
Route 10								
SP	1.0490	24.90	9.24	120		0.195201	1'-1½"	Pf 1.196
1508	16'-2"	24.90	5.6	19.773		Sprinkler,	5'-0"	Pe 0.488
727	15'-0½"			21.456		PO(5'-0)	6'-1½"	Pv
Route 11								
BL	1.4420	35.95	7.06	120		0.081758	458'-9"	Pf 39.935
437	29'-11"	151.35		43.720		PO(7'-5), Flow (q) from Route 14	29'-8½"	Pe
479	29'-11"			83.655		4E(3'-8½), PO(7'-5)	488'-5½"	Pv
CM	2.7050	151.35	8.45	120		0.054572	5'-10½"	Pf 1.342
479	29'-11"	115.40		83.655		Flow (q) from Route 12	18'-8½"	Pe
374	29'-11"			84.997		T(18'-8½)	24'-7"	Pv
Route 12								
CM	2.7050	115.40	6.44	120		0.033043	12'-9"	Pf 0.421
437	29'-11"	151.35		43.720		Flow (q) from Route 14		Pe
555	29'-11"			44.141			12'-9"	Pv
CM	2.7050	72.84	4.07	120		0.014104	13'-3"	Pf 0.187
555	29'-11"			44.141				Pe
660	29'-11"			44.328			13'-3"	Pv
BL	1.4420	36.44	7.16	120		0.083832	447'-0"	Pf 38.719
660	29'-11"			44.328		PO(7'-5)	14'-10½"	Pe
693	29'-11"			83.047		PO(7'-5)	461'-10½"	Pv
CM	2.7050	72.84	4.07	120		0.014104	13'-3"	Pf 0.187
693	29'-11"	36.40		83.047		Flow (q) from Route 13		Pe
591	29'-11"			83.234			13'-3"	Pv
CM	2.7050	115.40	6.44	120		0.033043	12'-9"	Pf 0.421
591	29'-11"	42.56		83.234		Flow (q) from Route 29		Pe
479	29'-11"			83.655			12'-9"	Pv
Route 13								
CM	2.7050	36.40	2.03	120		0.003908	11'-0"	Pf 0.043
660	29'-11"	36.44		44.328		Flow (q) from Route 12		Pe
780	29'-11"			44.371			11'-0"	Pv
BL	1.4420	36.40	7.15	120		0.083646	447'-0"	Pf 38.633
780	29'-11"			44.371		PO(7'-5)	14'-10½"	Pe
817	29'-11"			83.004		PO(7'-5)	461'-10½"	Pv
CM	2.7050	36.40	2.03	120		0.003908	11'-0"	Pf 0.043
817	29'-11"			83.004				Pe
693	29'-11"			83.047			11'-0"	Pv
Route 14								
CM	2.7050	194.73	10.87	120		0.086982	23'-9½"	Pf 3.698
395	29'-11"	40.32		39.714		Flow (q) from Route 1	18'-8½"	Pe
377	29'-11"			43.413		T(18'-8½)	42'-6"	Pv
CM	2.7050	151.35	8.45	120		0.054572	5'-7½"	Pf 0.307
377	29'-11"			43.413				Pe
437	29'-11"			43.720			5'-7½"	Pv
Route 15								
CM	2.7050	27.56	1.54	120		0.002336	11'-0"	Pf 0.026
170	15'-0½"	27.56		37.103		Flow (q) from Route 25		Pe
298	15'-0½"			37.129			11'-0"	Pv
CM	2.7050	55.20	3.08	120		0.008444	5'-10½"	Pf 0.208
298	15'-0½"	27.64		37.129		Flow (q) from Route 27	18'-8½"	Pe
382	15'-0½"			37.337		T(18'-8½)	24'-7"	Pv
Route 16								
BL	1.4420	2.50	0.49	120		0.000590	18'-11"	Pf 0.011
784	15'-0½"	3.73		101.520		Flow (q) from Route 24		Pe
781	15'-0½"			101.531			18'-11"	Pv
BL	1.4420	3.73	0.73	120		0.001235	83'-11½"	Pf 0.104
781	15'-0½"	1.23		101.531		Flow (q) from Route 17		Pe
770	15'-0½"			101.635			83'-11½"	Pv
BL	1.4420	2.49	0.49	120		0.000587	19'-4"	Pf 0.011
770	15'-0½"			101.635				Pe
767	15'-0½"			101.646			19'-4"	Pv



Hydraulic Analysis

Job Number: NC-1376

Report Description: Ordinary Group II (1 1st Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss		Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
BL	1.4420	3.73	0.73	120		0.001235	9'-5½"	Pf 0.021
767	15'-0½"	1.23		101.646		Flow (q) from Route 18	7'-5"	Pe
698	15'-0½"			101.667		PO(7'-5)	16'-11"	Pv
CM	2.7050	3.73	0.21	120		0.000058	11'-0"	Pf 0.001
698	15'-0½"			101.667				Pe
596	15'-0½"			101.668			11'-0"	Pv
CM	2.7050	7.56	0.42	120		0.000213	11'-0"	Pf 0.002
596	15'-0½"	3.83		101.668		Flow (q) from Route 30		Pe
494	15'-0½"			101.670			11'-0"	Pv
CM	2.7050	11.42	0.64	120		0.000458	12'-0"	Pf 0.005
494	15'-0½"	3.87		101.670		Flow (q) from Route 31		Pe
381	15'-0½"			101.675			12'-0"	Pv
CM	2.7050	15.11	0.84	120		0.000768	11'-0"	Pf 0.008
381	15'-0½"	3.68		101.675		Flow (q) from Route 33		Pe
273	15'-0½"			101.684			11'-0"	Pv
BL	1.4420	4.52	0.89	120		0.001764	168'-9½"	Pf 0.324
273	15'-0½"			101.684		PO(7'-5)	14'-10½"	Pe
293	15'-0½"			102.008		PO(7'-5)	183'-7½"	Pv
Route 17								
BL	1.4420	1.23	0.24	120		0.000158	40'-10"	Pf 0.011
784	15'-0½"	3.73		101.520		T(7'-5), Flow (q) from Route 24	29'-8½"	Pe
781	15'-0½"			101.531		3T(7'-5)	70'-7"	Pv
Route 18								
BL	1.4420	1.23	0.24	120		0.000160	41'-3"	Pf 0.011
770	15'-0½"			101.635		T(7'-5)	29'-8½"	Pe
767	15'-0½"			101.646		3T(7'-5)	71'-0"	Pv
Route 19								
CM	2.7050	43.38	2.42	120		0.005406	8'-10½"	Pf 0.048
377	29'-11"	151.35		43.413		Flow (q) from Route 14		Pe
231	29'-11"			43.461			8'-10½"	Pv
BL	1.4420	43.38	8.52	120		0.115717	274'-10"	Pf 34.812
231	29'-11"			43.461		PO(7'-5)	26'-0"	Pe
262	29'-11"			78.273		3E(3'-8½"), T(7'-5)	300'-10"	Pv
BL	1.4420	22.33	4.39	120		0.033884	178'-9"	Pf 6.308
262	29'-11"			78.273			7'-5"	Pe
264	29'-11"			84.581		PO(7'-5)	186'-2"	Pv
CM	2.7050	43.38	2.42	120		0.005406	6'-6"	Pf 0.035
264	29'-11"	21.04		84.581		Flow (q) from Route 20		Pe
373	29'-11"			84.617			6'-6"	Pv
Route 20								
BL	1.4420	21.04	4.13	120		0.030359	188'-9"	Pf 6.294
262	29'-11"			78.273		T(7'-5)	18'-7"	Pe
171	29'-11"			84.567		E(3'-8½"), PO(7'-5)	207'-4"	Pv
CM	2.7050	21.04	1.17	120		0.001418	10'-0"	Pf 0.014
171	29'-11"			84.567				Pe
264	29'-11"			84.581			10'-0"	Pv
Route 21								
BL	2.2030	21.75	1.83	120		0.004098	9'-0"	Pf 0.037
730	15'-0½"	2.97		21.160		Flow (q) from Route 6		Pe
731	15'-0½"			21.197			9'-0"	Pv
Route 22								
BL	1.4420	16.88	3.32	120		0.020184	49'-11"	Pf 1.608
716	15'-0½"			30.594		PO(7'-5)	29'-8½"	Pe
712	15'-0½"			32.201		2T(7'-5), PO(7'-5)	79'-8"	Pv
Route 23								
BL	1.4420	11.56	2.27	120		0.010017	11'-6"	Pf 0.115
849	15'-0½"	10.44		16.872		Flow (q) from Route 1		Pe
850	15'-0½"			16.987			11'-6"	Pv
Route 24								
CM	2.7050	15.11	0.84	120		0.000768	5'-7"	Pf 0.004
380	15'-0½"	219.94		101.417		Flow (q) from Route 1		Pe
400	15'-0½"			101.422			5'-7"	Pv
CM	2.7050	11.42	0.64	120		0.000458	12'-0"	Pf 0.005
400	15'-0½"			101.422				Pe
514	15'-0½"			101.427			12'-0"	Pv
CM	2.7050	7.56	0.42	120		0.000213	11'-0"	Pf 0.002
514	15'-0½"			101.427				Pe
616	15'-0½"			101.429			11'-0"	Pv



Hydraulic Analysis

Job Number: NC-1376

Report Description: Ordinary Group II (1 1st Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC		Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Fittings	Eq. Length	Summary
Upstream							Total Length	
CM	2.7050	3.73	0.21	120		0.000058	11'-0"	Pf 0.001
616	15'-0½"			101.429				Pe
719	15'-0½"			101.430			11'-0"	Pv
BL	1.4420	3.73	0.73	120		0.001235	50'-6½"	Pf 0.090
719	15'-0½"			101.430		PO(7'-5)	22'-3½"	Pe
784	15'-0½"			101.520		4E(3'-8½")	72'-10"	Pv
Route 25								
CM	2.7050	55.20	3.08	120		0.008444	11'-0"	Pf 0.093
411	15'-0½"			26.902				Pe
276	15'-0½"			26.995			11'-0"	Pv
CM	2.7050	27.56	1.54	120		0.002336	11'-0"	Pf 0.026
276	15'-0½"			26.995				Pe
194	15'-0½"			27.020			11'-0"	Pv
BL	1.4420	27.56	5.41	120		0.050009	186'-9"	Pf 10.083
194	15'-0½"			27.020		PO(7'-5)	14'-10½"	Pe
170	15'-0½"			37.103		PO(7'-5)	201'-7½"	Pv
Route 26								
BL	1.4420	24.28	4.77	120		0.039559	186'-9"	Pf 7.976
631	15'-0½"			26.411		PO(7'-5)	14'-10½"	Pe
605	15'-0½"			34.386		PO(7'-5)	201'-7½"	Pv
Route 27								
BL	1.4420	27.64	5.43	120		0.050263	186'-9"	Pf 10.134
276	15'-0½"			26.995		PO(7'-5)	14'-10½"	Pe
298	15'-0½"			37.129		PO(7'-5)	201'-7½"	Pv
Route 28								
CM	2.7050	78.71	4.39	120		0.016279	12'-0"	Pf 0.195
523	15'-0½"	24.56		26.706		Flow (q) from Route 3		Pe
411	15'-0½"			26.902			12'-0"	Pv
BL	1.4420	23.51	4.62	120		0.037267	198'-6"	Pf 8.645
411	15'-0½"			26.902		PO(7'-5)	33'-5½"	Pe
390	15'-0½"			35.546		T(7'-5), 3E(3'-8½"), PO(7'-5)	231'-11½"	Pv
Route 29								
BL	1.5300	42.56	7.43	120		0.083740	447'-0"	Pf 39.093
555	29'-11"			44.141		PO(9'-11)	19'-10"	Pe
591	29'-11"			83.234		PO(9'-11)	466'-10"	Pv
Route 30								
BL	1.4420	3.83	0.75	120		0.001297	168'-9½"	Pf 0.238
616	15'-0½"			101.429		PO(7'-5)	14'-10½"	Pe
596	15'-0½"			101.668		PO(7'-5)	183'-7½"	Pv
Route 31								
BL	1.4420	3.87	0.76	120		0.001323	168'-9½"	Pf 0.243
514	15'-0½"			101.427		PO(7'-5)	14'-10½"	Pe
494	15'-0½"			101.670		PO(7'-5)	183'-7½"	Pv
Route 32								
CM	2.7050	10.59	0.59	120		0.000398	11'-0"	Pf 0.004
273	15'-0½"	4.52		101.684		Flow (q) from Route 16		Pe
164	15'-0½"			101.688			11'-0"	Pv
BL	1.4420	10.59	2.08	120		0.008517	168'-9½"	Pf 1.564
164	15'-0½"			101.688		PO(7'-5)	14'-10½"	Pe
184	15'-0½"			103.252		PO(7'-5)	183'-7½"	Pv
Route 33								
BL	1.4420	3.68	0.72	120		0.001207	180'-7½"	Pf 0.254
400	15'-0½"			101.422		PO(7'-5)	29'-8½"	Pe
381	15'-0½"			101.675		4E(3'-8½"), PO(7'-5)	210'-4"	Pv

Equivalent Pipe Lengths of Valves and Fittings (C=120 only)

C Value Multiplier

$$\left(\frac{\text{Actual Inside Diameter}}{\text{Schedule 40 Steel Pipe Inside Diameter}} \right)^{4.87} = \text{Factor}$$

Value Of C	100	130	140	150
Multiplying Factor	0.713	1.16	1.33	1.51




Hydraulic Analysis

Job Number: NC-1376



Report Description: Ordinary Group II (1 1st Floor SW)

Pipe Type	Diameter	Flow	Velocity	HWC	Friction Loss	Length	Pressure
Downstream	Elevation	Discharge	K-Factor	Pt	Pn	Eq. Length	Summary
Upstream					Fittings	Total Length	

Pipe Type Legend	Units Legend	Fittings Legend
AO Arm-Over BL Branch Line CM Cross Main DN Drain DR Drop DY Dynamic FM Feed Main FR Feed Riser MS Miscellaneous OR Outrigger RN Riser Nipple SN Swing Nipple SP Sprig ST Stand Pipe UG Underground	Diameter Inch Elevation Foot Flow gpm Discharge gpm Velocity fps Pressure psi Length Foot Friction Loss psi/Foot HWC Hazen-Williams Constant Pt Total pressure at a point in a pipe Pn Normal pressure at a point in a pipe Pf Pressure loss due to friction between points Pe Pressure due to elevation difference between indicated points Pv Velocity pressure at a point in a pipe	ALV Alarm Valve AngV Angle Valve b Bushing BalV Ball Valve BFP Backflow Preventer BV Butterfly Valve C Cross Flow Turn 90° cplg Coupling Cr Cross Run CV Check Valve DelV Deluge Valve DPV Dry Pipe Valve E 90° Elbow EE 45° Elbow Ee1 11¼° Elbow Ee2 22½° Elbow f Flow Device fd Flex Drop FDC Fire Department Connection fE 90° FireLock(TM) Elbow fEE 45° FireLock(TM) Elbow flg Flange FN Floating Node fT FireLock(TM) Tee g Gauge GloV Globe Valve GV Gate Valve Ho Hose Hose Hose HV Hose Valve Hyd Hydrant LtE Long Turn Elbow mecT Mechanical Tee Noz Nozzle P1 Pump In P2 Pump Out PIV Post Indicating Valve PO Pipe Outlet PRV Pressure Reducing Valve PrV Pressure Relief Valve red Reducer/Adapter S Supply sCV Swing Check Valve Spr Sprinkler St Strainer T Tee Flow Turn 90° Tr Tee Run U Union WirF Wirsbo WMV Water Meter Valve Z Cap




Supply Flow Test Data	
Test Conducted By	Lees Summit
Date of Test	5-5-23
Location	Paragon Parkway Lees Summit
Static Pressure	105.000
Residual Pressure	68.000
Flow	2200.00





- 1: 8" NEW FIRE LINE BY OTHERS. HYDROSTATIC & FLUSHING INSPECTIONS PERFORMED PER NFPA AND AHJ STANDARDS. NFPA INSPECTION FORMS TO BE FILLED OUT BY INSTALLING CONTRACTOR.
- 2: 8" SPLIT FLANGE & BOLT PACK ATTACHED TO FIRELINE ABOVEGROUND SPIGOT FLANGE TERMINATING 1'-6" ABOVE FINISHED FLOOR.
- 3: 8" X 3" CONCENTRIC REDUCER.
- 4: 3" DERRINGER 30 BFP DOUBLE CHECK DETECTOR. PER AHJ STANDARDS. ALARM WIRING AND MONITORING BY OTHERS.
- 5: 3" GRV CHECK VALVE, 4" 30 DEGREE STORZ FDC PER AHJ REQUIREMENTS, 1/2" BALL DRIP OFF DRAIN T PIPED TO EXTERIOR
- 6: 2-1/2" DRY PIPE VALVE TYCO DPV-1, 2-1/2" SUPPLY TO DRY SYSTEM WALKWAY. RISER MOUNT OIL-LESS AIR COMPRESSOR, WIRING BY OTHERS. (70 GAL. CAPACITY)
- 7: 3" FLUSHING T WITH CAP.
- 8: 3" FLOW SWITCH. ALARM WIRING AND MONITORING BY OTHERS.
- 9: WATER PRESSURE GAUGE ASSEMBLY.
- 10: 1-1/4" GROOVED AGF TEST N DRAIN WITH 1/2" PRV & K5.6 ORIFICE.
- 11: 1-1/4" GALVANIZED 45 ON SYSTEM DRAIN PIPED TO EXTERIOR.
- 12: GENERAL INFORMATION SIGNAGE. INSTALL VALVE ID SIGNS.
- 13: SPARE HEAD BOX WITH WRENCH PER NFPA13 6.2.9.
- 14: MANUAL AIR VENT NEAR HIGHEST POINT IN SYSTEM PER NFPA13 8.16.6 (1" GLOBE VALVE WITH PLUG).

First Floor East
0-1/8" = 1 Foot

UPRIGHTS ON 1" SPRIGS, HEADS
0-10" FROM DECK



First Floor West
0-1/8" = 1 Foot



Hydraulic Information	
Remote Area 1 1st Floor SW	
OCCUPANCY CLASSIFICATION	Ordinary Group II
DENSITY (gpm/ft²)	0.20 for 1500.00 ft² (Actual 1097.54 ft²)
QUICK RESPONSE REDUCTION	17'-0" Ceiling (28.5%) 1057.50 ft²
TOTAL HOSE STREAMS	250.00
TOTAL HEADS FLOWING	10
K-FACTOR	5.6
TOTAL WATER REQUIRED	485.05
TOTAL PRESSURE REQUIRED	126.350
BASE of RISER (gpm)	235.05
BASE of RISER (psi)	114.024
SAFETY MARGIN (psi)	+34.674 (21.7%)

Hydraulic Information	
Remote Area 2 Dry Walkway	
OCCUPANCY CLASSIFICATION	Light Hazard
DENSITY (gpm/ft²)	0.10 for 1950.00 ft² (Actual 2039.92 ft²)
TOTAL HOSE STREAMS	100.00
TOTAL HEADS FLOWING	12
K-FACTOR	5.6
TOTAL WATER REQUIRED	341.30
TOTAL PRESSURE REQUIRED	93.563
BASE of RISER (gpm)	0.00
BASE of RISER (psi)	83.018
SAFETY MARGIN (psi)	+69.318 (42.6%)

Sprinkler Legend										
Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature
○	Viking	UK300	Microfast	576	5.6	Upright	1 1/2"	Quick	Brass	175 °F
●	Tyco	TY3255	DS-1	48	5.6	Pendent	1"	Quick	Chrome	175 °F
●	Viking	VK305	Microfast	9	5.6	Sidewall	1 1/2"	Quick	Chrome	155 °F
●	Viking	VK4621		14	5.6	Pendent	1"	Quick	Brass	175 °F
				Total = 647						
										Note
										1" Sprig
										Dry head
										White Coverplate

1. FIRE SPRINKLER DESIGN PER NFPA 13 2016 EDITION.
2. OWNER SHALL MAINTAIN SYSTEM PER NFPA 25.
3. ALL MATERIALS USED SHALL COMPLY WITH SPECIFIED REQUIREMENTS.
4. CONTINUOUS CENTRAL MONITORING OF ALARM COMPONENTS PER NFPA 72 SHALL BE BY OTHERS.
5. ALL ALARM AND ELECTRICAL WORK ASSOCIATED WITH INSTALLED COMPONENTS SHALL BE BY OTHERS.
6. ALL UNDERGROUND WORK BY OTHERS. FIRE LINE SHALL BE FLUSHED PER NFPA 24 REQUIREMENTS OVER AND ABOVE LOCAL WATER JURISDICTION REQUIREMENTS. NFPA TEST PAPERS FILLED OUT AND SIGNED BY INSTALLER SHALL BE SUBMITTED TO GENERAL CONTRACTOR PRIOR TO THE ABOVEGROUND SYSTEM BEING PUT INTO SERVICE.
7. ANY PAINTING OF PIPE BY OTHERS.
8. CONDITIONING OF BUILDING ENVELOPE TO PREVENT WATER FREEZING IN PIPES SHALL BE BY OTHERS BEFORE AND AFTER OCCUPANCY.
9. ANY LABELING OF PIPE BY OTHERS.
10. 6" & 8" PIPE WITH GROOVED ENDS SHOULD BE SCHEDULE 10. 4"-1 1/2" SHOULD BE SCHEDULE 7 EDDY FLOW.
11. PIPE WITH THREADED ENDS SHALL BE SCHEDULE 40.

REVISIONS:

SCALE: 1/8" = 1'



JOB NAME:
Paragon Star BLD 2 Lot 9
3201 NW Paragon Parkway Lee's Summit MO

DRAWN BY: DB
DATE: 5-24-23
JOB #: NC 1376

SHEET NO:
1 OF 2





CONTRACTOR:
Fogel-Anderson
1212 E 8th St, Kansas City, MO 64106



Building Construction Type:
Non-combustible obstructed construction

Ordinary Hazard 2 & light in 1st floor retail
Light hazard on 2nd floor

PLOT DATE: 05/24/23 FILE NAME: NC-1376 Paragon Star #2 draw



SEAL:

5-24-23

FOGEL-ANDERSON
EST. 1917

Building Construction Type:
Non-combustible obstructed construction

Ordinary Hazard 2 & light in 1st floor retail

Light hazard on 2nd floor

Sprinkler Legend											
Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Note
	Viking	VK300	Microfast	576	5.6	Upright	1/2"	Quick	Brass	175 °F	1" Sprig
	Tyco	TY3255	DS-1	48	5.6	Pendant	1"	Quick	Chrome	175 °F	Dry head
	Viking	VK305	Microfast	9	5.6	Sidewall	1/2"	Quick	Chrome	155 °F	
	Viking	VK4621		14	5.6	Pendant	1/2"	Quick	Brass	175 °F	White Coverplate
				Total = 647							

1. FIRE SPRINKLER DESIGN PER NFPA 13 2016 EDITION.
2. OWNER SHALL MAINTAIN SYSTEM PER NFPA 25.
3. ALL MATERIALS USED SHALL COMPLY WITH SPECIFIED REQUIREMENTS.
4. CONTINUOUS CENTRAL MONITORING OF ALARM COMPONENTS PER NFPA 72 SHALL BE BY OTHERS.
5. ALL ALARM AND ELECTRICAL WORK ASSOCIATED WITH INSTALLED COMPONENTS SHALL BE BY OTHERS.
6. ALL UNDERGROUND WORK BY OTHERS. FIRE LINE SHALL BE FLUSHED PER NFPA 24 REQUIREMENTS OVER AND ABOVE LOCAL WATER JURISDICTION REQUIREMENTS. NFPA TEST PAPERS FILLED OUT AND SIGNED BY INSTALLER SHALL BE SUBMITTED TO GENERAL CONTRACTOR PRIOR TO THE ABOVEGROUND SYSTEM BEING PUT INTO SERVICE.
7. ANY PAINTING OF PIPE BY OTHERS.
8. CONDITIONING OF BUILDING ENVELOPE TO PREVENT WATER FREEZING IN PIPES SHALL BE BY OTHERS BEFORE AND AFTER OCCUPANCY.
9. ANY LABELING OF PIPE BY OTHERS.
10. 6" & 8" PIPE WITH GROOVED ENDS SHOULD BE SCHEDULE 10. 4"-1 1/2" SHOULD BE SCHEDULE 7 EDDY FLOW.
11. PIPE WITH THREADED ENDS SHALL BE SCHEDULE 40.

REVISIONS:

SCALE: 1/8" = 1'

Alliance FIRE PROTECTION

130 W 9th Ave, Suite 101
North Kansas City, MO 64116
PH: 913-888-0647 FAX: 913-888-0618
WWW.AFPSPRINK.COM

DRAWN BY: DB

DATE: 5-24-23

JOB #: NC 1376

SHEET NO: 2 OF 2

JOB NAME: Paragon Star BLD 2 Lot 9
3201 NW Paragon Parkway Lee's Summit MO

CONTRACTOR: Fogel-Anderson
1212 E 8th St, Kansas City, MO 64106