

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232261
Address: 1528 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, May 30, 2023

Corrective Action Required:

1	Misc	-fire block wall space to ceiling space at furr down above pool area -fire block wall space to ceiling space/ furr down basement bed closet -move electrical outlets in bed closet ceiling to ceiling height out of furr down.
---	------	--

Comments: