

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226244
Address: 213 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Deck Final Inspection - Residential	Shawn Hoffman	Failed	Tuesday, May 30, 2023

Corrective Action Required:

1	Misc	- R507.5.1(2) Provide (2) 1/2" through bolts on each vertical post at to the beam connection. (not to joist)
---	------	--

Comments: