

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222344  
Address: 224 SW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Tuesday, May 30, 2023

Corrective Action Required:

1	Misc	-Complete all corrections for LSFD -Provide address at front and rear entry -Provide electrical panel doors, labels, and schedules -Restroom signage to be on latch side of both doors -Non absorbant wall finish in restrooms must be min 48" aff -Mirrors to be max 40" to reflective surface -Install cover plates at mechanical room -Stair handrail must extend 12" past last tread
---	------	---

**Comments:**