

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20111353, Building Permit - Commercial Address: 122 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Rough Mechanical John Borns Failed Thursday, June 09, 2011

Inspection - Commercial

Corrective Action Required

1 MISC FURNACE TO BE RELOCATED TO PROVIDE 30"W x 36" DEEP

MINIMUM CLEARANCE IN FRONT OF ELECTRICAL SERVICE

PANEL

Underslab Plumbing John Borns

. . ..

Inspection - Commercial

Passed Thursday, June 09, 2011

Comments: OK TO COVER WHEN READY UNDER-SLAB DWV PLUMBING PIPING.