



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20111353, Building Permit - Commercial  
Address: 122 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Mechanical Inspection - Commercial</b>	John Borns	Failed	Thursday, June 09, 2011

Corrective Action Required

1	MISC	FURNACE TO BE RELOCATED TO PROVIDE 30"W x 36" DEEP MINIMUM CLEARANCE IN FRONT OF ELECTRICAL SERVICE PANEL
---	------	---

<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Passed	Thursday, June 09, 2011
---	------------	--------	-------------------------

**Comments: OK TO COVER WHEN READY UNDER-SLAB WATER TUBING + DWV PLUMBING PIPING.**