

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216100
Address: 4813 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Wednesday, May 31, 2023

Corrective Action Required:

1 DCM3 ESC
REQUIRED 2 DAY

EROSION CONTROL REQUIRED ALONG THE STREET.

STREET CLEANUP SHALL BE PERFORMED IMMEDIATELY. MUD&SILT SHALL BE CLEANED OFF THE STREET CURB AND STORM INLET. PROTECT STORM INLET WITH GUTTER BUDDY IN SUCH WAY TO ALSO ALLOW STORM WATER DRAINAGE.

EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. FAILURE TO COMPLY WITH THE EROSION CONTROL REQUIREMENT WILL RESULT IN ISSUANCE OF A STOP-WORK ORDER

Comments: