

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215979
Address: 110 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - R	Shawn Hoffman	Failed	Thursday, June 01, 2023

Corrective Action Required:

1	Misc	- add gravel to meter pit - meter to be 14-18" from rim of pit. sitting at 12" now.
---	------	--

Comments: