

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224991

Address: 2037 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, June 01, 2023

Corrective Action Required:

1 Misc

- fireblock s garage furred out wall to ceiling space
- fireblock hvac chase to ceiling space
- missing 3 stud pack at coat closet (address broken stud at this area as well)
- fireblock fireplace to ceiling space
- missing 3 stud pack at bed 3/4 bath E wall
- fireblock master closet entry wall to ceiling space

Comments: