

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222877
Address: 2105 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Friday, June 02, 2023

Corrective Action Required:

1	Misc	MAINTAIN EROSION CONTROL-Restore silt fence at perimeter and maintain gravel filter with min 6" lift of 3/4" gravel. Address erosion control before rescheduling -address rafters landing on blocks throughout garage -address rafters landing on blocks throughout upstairs -strap top plate at same location-Strap top plates lapped less than 24" at master bed wall/ master bath intersecting wall location and at master bath/ master closet location (marked on the walls)
---	------	---

Comments: