



**CITY OF LEE'S SUMMIT
CODES ADMINISTRATION**

220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20110540
Address: 2810 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064
Inspected On: Friday, June 10, 2011
Inspected By: Joe Dir Khanh Nguyen Khanh Nguyen
Expiration Date: 7/8/2011 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Alarm Test	Joe Dir	Passed	Friday, June 10, 2011
Gas Piping Inspection - Commercial	Khanh Nguyen	Passed	Friday, June 10, 2011
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, June 10, 2011

Corrective Action Required:

1	MISC	ROOFTOP PIPING SUPPORT BLOCKS: 1) REQUIRE SLIP SHEETS TO PROTECT ROOF MEMBRANE 2) ALL TO BE IN CONTACT WITH ROOF AND AT CODE-COMPLIANT SPACING 3) ALL CLAMPS TO BE SCREWED TO BLOCKS 4) STACKED BLOCKS MUST BE FASTENED TOGETHER
---	------	--

Comments: