



**CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION**

220 SE GREEN ST.  
P.O.BOX 1600

**PHONE:**  
816-969-1200

**FAX:**  
816-969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20110540  
**Address:** 2810 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064  
**Inspected On:** Friday, June 10, 2011  
**Inspected By:** Joe DirKhanh NguyenKhanh Nguyen  
**Expiration Date:** 7/8/2011 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Alarm Test</b>	Joe Dir	Passed	Friday, June 10, 2011
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Temporary C of O	Friday, June 10, 2011

**Corrective Action Required:**

1	MISC	ROOFTOP PIPING SUPPORT BLOCKS: 1) REQUIRE SLIP SHEETS TO PROTECT ROOF MEMBRANE 2) ALL TO BE IN CONTACT WITH ROOF AND AT CODE-COMPLIANT SPACING 3) ALL CLAMPS TO BE SCREWED TO BLOCKS 4) STACKED BLOCKS MUST BE FASTENED TOGETHER
---	------	--

**Comments:**