

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231769  
Address: 2113 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Residential</b>	Robb Popp	Failed	Tuesday, June 06, 2023

Corrective Action Required:

1	Misc	-Provide combustion air openings -Install secondary lock at sliding glass door
---	------	---

**Comments:**