

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216461
Address: 3132 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------------|----------|------------------------|
| Pool Steel/Bonding - Commercial | Mitchell Schwarz | Passed | Tuesday, June 06, 2023 |

| | |
|----------------|--|
| Informational: | |
| 1 Misc | inspected 3 water features N end of pool, Water bond located in skimmer closest to those pool features E side. rebar sticking out to tie into deck at 6 locations okay to pour shell |
| Informational: | |
| 2 Misc | poll deck and perimeter bonded 1 handrail, 1 ladder, 1 ada chair lift bonded Pool equipment bonded |

Comments: