

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192646  
Address: 3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Fire Line - Hydrostatic Test</b>	John Jackson	Passed	Tuesday, June 06, 2023

Informational:  
1      Misc      06/06/23 JMJ ( SDI - SHE DIG IT - Foreman Shawn )  
Contractor test approximately 25' of 6" DIP water pipe including riser inside building frame. Contractor wanted to ensure this portion passed before floor slab was poured.

**Comments:**