

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192646
Address: 3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--------------------------------------|--------------|----------|------------------------|
| Water Line - Hydrostatic Test | John Jackson | Passed | Tuesday, June 06, 2023 |

Informational:
1 Misc 06/06/25 Tuesday JMJ (SDI- Shawn)
Contractor tested approximately 25' of 4" DIP domestic water line including riser that is in the frame of building. Contractor wanted to test this portion to verify it passed before concrete slab was poured.

Comments: