

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231576  
Address: 1029 SW ARMIE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, June 07, 2023

Corrective Action Required:

1	Misc	Portal frame and front porch cover only
		- portal frame ok to cover, missing anchor bolts, washers, nuts
		- front porch- full joist above door has insufficient bearing, provide hangers.

**Comments:**