

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231576
Address: 1029 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Shawn Hoffman	Failed	Wednesday, June 07, 2023

Corrective Action Required:

1	DCM2 ESC	-PROVIDE SILT FENCE OF SWADDLES AT FRONT OF LOT.
	DEFICIENT	- REMOVE CONSTRUCTION TRASH
	INSTALLATION	- PROVIDE EROSION CONTROL AROUND SPOILAGE PILE

Comments: