## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Temporary** Certificate of Occupancy

Permit #:	PRRES20221108
Address:	3104 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082
Inspected On:	Wednesday, June 07, 2023
Inspected By:	Mitchell Schwarz
<b>Expiration Date:</b>	7/7/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspectio	on:	Inspector:	Outcome:	Date:		
•	ncy Inspection - esidential	Mitchell Schwarz	Pending			
Corrective Action Required:						
1	Misc	-final grade				
		-sod				
	-splash blocks and sump pump discharge to extend 36" f					
-landing at bottom o			tairs at deck must be 36	5" in the direction of		
		travel				
		-2 1/2" through bolts at each deck post to beam connection				
		-uncover covered manhole				