

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20215277

Address: 3671 NE AKIN DR, Unit:A, LEES SUMMIT, MO 640643671 NE AKIN DR, Unit:C, LEES SUMMIT, MO  
640643671 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643671 NE AKIN DR, Unit:B, LEES  
SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Wednesday, June 07, 2023

Corrective Action Required:

1	Misc	EXTERIOR: -Downspout splash blocks -Seal exterior lights, wall penetrations, seal/flash above&behind service equipment, etc  UNIT A: -Install kitchen island receptacle cover plate  UNIT B: -Fix patio gfci receptacle keeps tripping  UNIT C: -Install water heater P&T discharge pipe  UNIT D-OK
---	------	--

**Comments:**