

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223368
Address: 2911 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Nick Scott	Failed	Thursday, June 08, 2023

Corrective Action Required:

1	Misc	6-8-23 NS Site visited Sidewalk ramp did not pass ADA. There is no 5 foot turn around for a person that is in a wheel chair. This will need to be tore out and replaced to meet ADA standards. Please call me Nick Scott at 816-977-5652 to meet up and I can explain what needs to change.
---	------	---

Comments: