

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220773
Address: 3213 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, June 08, 2023

Corrective Action Required:

1	Misc	-Provide arc fault protection for all kitchen outlets. See refrigerator -provide 14"-18" depth at water meter from meter top to well lid ring while maintaining meter lid flush with grade
---	------	---

Comments: