

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225303
Address: 901 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Partial	Thursday, June 08, 2023

Corrective Action Required:

1	Misc	-Protect all dwv within 1.25" to face of framing at studs and extend 2" above and below flanges of top and bottom track
---	------	---

**Ok to cover exterior walls, top out for hard lids and one side other areas-DO NOT COVER INSPECTION ITEMS

Comments: