

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20216461
Address: 3132 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mitchell Schwarz	Failed	Thursday, June 08, 2023

Corrective Action Required:

1	Misc	-panic hardware At all exits -handrail at side exit stairs -underground conduit for light poles to be inspected, 18" deep for non-driving services, 24" for drivable surfaces -woman's accessible toilet flush handle to be on accessible side -anti syphon device on water spigot in pump room -address all other departments items
---	------	---

Comments: