

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20216461
Address: 3132 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082
Inspected On: Friday, June 09, 2023
Inspected By: Mark Harding
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Temporary C of O	Friday, June 09, 2023

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -panic hardware At all exits
-handrail at side exit stairs shall extend 12" past top and bottom riser. See code section 1014.6
-underground conduit for light poles to be inspected, 18" deep for non-driving services, 24" for drivable surfaces
-woman's accessible toilet flush handle to be on accessible side
-anti syphon device on water spigot in pump room
-address all other departments items |
|---|------|---|

Corrective Action Required:

- | | | |
|---|------|---|
| 2 | Misc | Tco issued based on teh converstaion on 6/6 .
signage has been installed for egress.
Tco good for 7 days.
contact our office prior to next friday. |
|---|------|---|

