

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220890

Address: 1081 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811083 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811085 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811087 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811089 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811079 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Engineering	Devon Perry	Temporary C of O	Monday, June 12, 2023

Corrective Action Required:

1	Miscellaneous Correction	6-12-23 TCO is granted for engineering. Below I will have a punch list for items that need addressed <ul style="list-style-type: none">- Clean up site- Grading and backfill- Vegetation- Erosion control measures until vegetation takes place- Paint Fire Hydrant bonnets Silver- Install no parking signs on fire hydrant side of street- Remove dumpsters and construction material-Sweep Black Twig Cir
---	--------------------------	---

Comments: