

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231096

Address: 2022 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822024 SW HOLDBROOKS DR, LEES SUMMIT,  
MO 640822026 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822028 SW HOLDBROOKS  
DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Kyle Beard	Failed	Tuesday, June 13, 2023

Corrective Action Required:

- |   |                             |  |
|---|-----------------------------|--|
| 1 | Miscellaneous<br>Correction | <ul style="list-style-type: none"><li>- 2024 is missing fire blocking in the basement west wall ceiling</li><li>- 2022 is missing fire blocking by kitchen in the vertical wall</li><li>- fire blocking is needed around all metal conduit pipes in all units that breach the fire walls for electrical wiring</li></ul> |
|---|-----------------------------|--|

**Comments:**