

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216099
Address: 4728 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Khanh Nguyen	Failed	Wednesday, June 14, 2023

Corrective Action Required:

1	Misc	Deck has been enlarged from approved plan. The enlarged deck joists on the north side are way over-spanned. Submit revised plan for the deck
---	------	--

****The three 24" diameter piers on original plan are ok to pour**

Comments: