CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20220898

Address: 1013 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811015 NW BLACK

TWIG CIR, LEES SUMMIT, MO 640811017 NW BLACK TWIG CIR, LEES SUMMIT, MO 640811019 NW BLACK TWIG CIR, LEES SUMMIT, MO

640811011 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

Inspected On: Wednesday, June 14, 2023

Inspected By: Robb Popp

Expiration Date: 7/14/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Robb

Codes Commercial

Robb Popp Pending

Corrective Action Required:

1 Misc -Complete final grade, sod, downspout extensions, etc.

-Seal exterior penetrations

-All water meters to be 14"-18" to top of meter pit