

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226253
Address: 3223 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mitchell Schwarz	Not Ready	Thursday, June 15, 2023

Corrective Action Required:

1	Misc	NO ACCESS FOR INSPECTION CALLED NUMBER ON INSPECTION
		-Provide shut off within 12" of disconnect at fireplace
		-repair/replace damaged csst above basement bedroom

Comments: