



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110702, Building Permit - Commercial
Address: 425 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Tuesday, June 14, 2011

Corrective Action Required
1 MISC

IPC 305.8: INSTALL SHIELD PLATES AT STUDS & TRACKS. SHIELD PLATES SHALL COVER THE AREA OF THE MEMBER WHERE THE PIPE PENETRATES AND SHALL EXTEND A MINIMUM OF 2" ABOVE BASE TRACKS & BELOW TOP TRACKS. CHECK ALL.

Comments: