

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20222910
Address: 3107 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, June 16, 2023

Corrective Action Required:

1	Misc	-sod -splash blocks and sump pump discharge to extend 36" from foundation -bring water meter to grade -outlet required left of fireplace -spark ring for outlets at mud room sink counter space -outlets along garage E wall hot/neu. Reverse -pantry door to be self closing and latching -refrigerator to be afci protected -lable all non GFCI outlets in unfinished spaces see sump pump
---	------	--

Comments: