

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20224767
Address: 1100 NW MAIN ST, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Partial	Friday, June 16, 2023

Corrective Action Required:

1	Misc	Pump room near CL 5 -Provide protection plates at top and bottom track for vent line
		Penthouse -Incomplete

Informational:

2	Misc	Areas approved to rock: Unit D TI except 117,120,11a, 127,128, 129,130, 125, 126,117,120
---	------	--

Comments: