



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20225294	Date:	June 16, 2023
Project Title:	FIRE STATION #4	Applicant:	
Location:			
5031 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064		ENVISION TECHNOLOGY GROUP	
Type of Work:		6985 W 153RD ST	
Occupancy Group:	MIX	OVERLAND PARK, KS 66223	
Description:	NEW FIRE STATION #4		
Construction Type:	Type IIB (Unprotected)	Primary:	(913) 491-1700
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Rejected

1. How is the system being monitored?

6/14/2023- No response. The alarm system shall be remote monitored by Fire Communications (816) 969-7360.

2. Why are there 135CD horn/strobe in the bunk rooms?

6/14/2023- No response, reduce candella.

3. Provide a relay for the kitchen hood system/fire suppression.

4. Provide equipment specifications.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.