

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220630
Address: 1249 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, June 19, 2023

Corrective Action Required:

1	Misc	-Install splash block at rear downspout and sump pump extension -Drive grounding rod into ground -Support lawn irrigation pex line every 32" -Provide max 35 amp breaker for AC
---	------	--

Comments: