

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20230960  
Address: 1138 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Tuesday, June 20, 2023

Corrective Action Required:

1	Misc	-Complete corrections for LSFD -ADA drinking fountain to have min. 27" clearance for knee space -Grab bars at back wall in restrooms to be 6" from side wall -Provide grab bars in shower stall -Label electrical panels -Provide address on back doors -Provide hammer arrestors at washer
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**