

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215274
Address: 3695 NE AKIN DR, Unit:B, LEES SUMMIT, MO 640643695 NE AKIN DR, Unit:C, LEES SUMMIT, MO 640643695 NE AKIN DR, Unit:D, LEES SUMMIT, MO 640643695 NE AKIN DR, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Wednesday, June 21, 2023

Corrective Action Required:

1	Misc	**Approval required from: Planning, Water, Field Service
		-Lot drainage issue-standing water
		-Complete outdoor receptacle outside unit D

Comments: