

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215017
Address: 126 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, June 21, 2023

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Obtain an irrigation permit- Label non gfci outlet at sump- Provide (2) 1/2" through bolts on each post to beam connections at deck- Center post at deck railing loose- Secure A/C whip at compressor within 12" of disconnect- Provide splash pads- Label non gfci outlet in garage |
|---|------|--|

Comments: