

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20231815  
Address: 2614 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	Mitchell Schwarz	Failed	Wednesday, June 21, 2023

Informational:

1 Misc

- Footing Bonded at 4 points around the perimeter of the pool to tie to the foundation walls
- foundation walls bonded
- pool floor bonded
- hot tub seat bonded

No bonding to be inspected 6/16/23

perimeter bonding NW and NE side of pool okay  
for Sw and Se perimeter bonding shall comply with SECTION E4202.2.  
(2)perimeter serfaces of 2018 irc

**Comments:**