CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20214608

Address: 916 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081918 NW BLACK TWIG

CIR, LEES SUMMIT, MO 64081920 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081922 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081924 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081926 NW BLACK TWIG CIR, LEES

SUMMIT, MO 64081928 NW BLACK TWIG CIR, LEES SUMMIT, MO

64081914 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081

Inspected On: Wednesday, June 21, 2023

Inspected By: Robb Popp

Expiration Date: 7/21/2023 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Robb Popp Pending

Codes Commercial

Corrective Action Required:

1 Misc Final grade/sod

-siding requires 6" clearance to grade

Foundation drainage must extend 36" from foundation