

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216531
Address: 1708 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Thursday, June 22, 2023

Corrective Action Required:

1	Miscellaneous Correction	<ul style="list-style-type: none">- Dishwasher is not on a GFCI breaker- House to garage door self closing hinge is not working- Vertical boards at ceiling in garage need to be sealed- Top is A/C disconnect needs to be sealed- Two 6x6 porch post supporting the stair platform need (2) 1/2 inch through bolts installed
---	--------------------------	---

Comments: